



- NOTES:
1. VALVE CONTROLLED BY CONTAINMENT PRESSURE SENSOR SET TO OPEN AT 0.5 PSIG CONTAINMENT PRESSURE.
 2. FLANGES TO BE USED FOR PENETRATION TESTING.
 3. CLASS F PIPE DUE TO FLOODING POTENTIAL TO SAFETY EQUIPMENT.

DESIGN PARAMETERS

LINE LISTING	PRESSURE	TEMPERATURE	CLASS	NOTES
01	115 PSIG	150°F	F	
02	115 PSIG	150°F	F	
03	115 PSIG	150°F	F	
04	115 PSIG	150°F	F	
05	115 PSIG	150°F	F	
06	115 PSIG	150°F	F	
07	115 PSIG	150°F	F	
08	115 PSIG	150°F	F	
09	115 PSIG	150°F	F	
10	115 PSIG	150°F	F	
11	115 PSIG	150°F	F	
12	115 PSIG	150°F	F	
13	115 PSIG	150°F	F	
14	115 PSIG	150°F	F	

NO.	REVISIONS	DATE	BY	CHKD	APP'D	SCALE

OF CONDITION 4
OF CONDITION 1
DUKE POWER COMPANY
WISCONSIN NUCLEAR STATION UNIT 2

FLOW DIAGRAM OF
CONTAINMENT VENTILATION
COOLING WATER SYSTEM
(CW)

DATE: 12/28/61
SCALE: AS SHOWN
DWG. NO. MC-2001-1.0
SHEET 14

FOR
INFORMATION
ONLY

SI
APERTURE
CARD

8903220342

PDR RIDS

