

- NOTES**
1. ALL GATE VALVES WITH ALARMS THIS DWG WILL ALARM WHEN CLOSED.
  2. VALVES TO BE PROVIDED BY VENDOR.
  3. ALL ANNUNCIATORS SHALL BE DISPLAYED ON THE LOCAL FIRE CONTROL PANEL THRU THE PLANT COMPUTER IN THE CONTROL ROOM.
  4. ALL INSTRUMENTS SHOWN ON THIS DWG ARE PROVIDED BY THE UNIT NO. 0 UNLESS OTHERWISE NOTED.
  5. ALL PIPING VALVES ARE TO BE PROVIDED BY MECHANICAL GROUP THE PROTECTION ENGINEER IN ACCORDANCE WITH APPLICABLE SPECIFICATIONS.
  6. OVERFLOW LINE TO BE SIZED AND PROVIDED BY TANK VENDOR.
  7. ALL PIPING VALVES, COMPONENTS SHOWN ON THIS DRAWING ARE NON-SEISMICALLY DESIGNED.

**REFERENCE DWGS**  
 1. SABINE STEEL CONSTRUCTION CO. (TANK VENDOR DWGS)

**TERA APERTURE CARD**

**INFORMATION**  
 THIS DOCUMENT IS SUBJECT TO REVISION WITHOUT NOTIFICATION TO THE USER OF THIS COPY

NO.	DATE	DESCRIPTION	BY	CHKD	APP'D
C	10-10-78	WORD TEST HEAD ADDED DIESEL EXHAUST, REVISED LINE NOS. AS NOTED	RLD	WJS	
B	4-17-78	USE WAS CONST. PER MGMT. DECISION, REVISED AS NOTED, ADDED NOZZLE REPS	FNA	WJS	
I	1-6-77	REV TR FILLING, ADD LINE SIDE, REMOVED HOLD	WJS	WJS	
D	10-27-74	REWORK DRAWING, REV. AS NOTED	WJS	WJS	
A	4-2-76	PROPOSED REVISION	WJS	WJS	

**Brown & Root, Inc.**

**SOUTH TEXAS PROJECT**


PIPING DIAGRAM  
 FIRE PROTECTION STORAGE AND PUMPS

CONTRACT NO. CR-0241  
 DRAWING NO. 9Q-27  
 O-F-0006-C

SCALE: AS SHOWN

DATE: OCT. 10 1978

PRELIMINARY REVIEW USE CONSTRUCTION



17"  
 11"  
 8.5"  
 8.5"  
 11"  
 8.5"  
 11"  
 17"

17"  
 11"  
 8.5"  
 8.5"  
 11"  
 8.5"  
 11"  
 17"

RIDS

8112170311

