



EACH CCW PUMP IS DESIGNED FOR 17000 GPM @ 110 PSI (120 FT) SHUT OFF HEAD @ 30 PSI/100 GPM

NOTE: SEE DIAG. PO-12B FOR CONTROL VALVE FUNCTIONS

- LEGEND:
- CONDENSER
- CCW INTRINSIC SAFETY SYSTEM
- CCW DISCHARGE
- BEARING WATER

17	REV PER C.C. 1318-03	W.C. COOPER
18	REV PER C.C. 1330-02	W.C. COOPER
19	REV PER C.C. 1338-04	W.C. COOPER
20	REV PER C.C. 1344	W.C. COOPER
21	REV PER C.C. 1344	W.C. COOPER
22	REV PER C.C. 1344	W.C. COOPER
23	REV PER C.C. 1344	W.C. COOPER
24	REV PER C.C. 1344	W.C. COOPER
25	REV PER C.C. 1344	W.C. COOPER
26	REV PER C.C. 1344	W.C. COOPER

TERA APERTURE CARD

DUKE POWER COMPANY
 OCOONEE NUCLEAR STATION UNIT NO. 3
 DIAGRAMMATIC LAYOUT
 OF
 CONDENSER CIRCULATING WATER SYSTEM

8001080 827

11

11

9.8

8.5"

11"

17"

8001080827

