



TI APERTURE CARD

REF ID	DESCRIPTION	SYSTEM TITLE
DER-500-795-4	RESIDUAL HEAT REMOVAL	RESIDUAL HEAT REMOVAL
DER-750-798-212-1	FLOOR AND EQUIPMENT DRAINS	FLOOR AND EQUIPMENT DRAINS

- NOTES:
1. ALL LINE, INSTRUMENT, VALVE AND EQUIPMENT TAGGERS TO BE PREFIXED WITH "CSL" EXCEPT WHERE A DIFFERENT PREFIX IS SHOWN.
 2. SPOOL PIECE SHALL BE INSTALLED ONLY DURING PLANT SHUTDOWN.
 3. THE DASH (-) IN THE SYSTEM PREFIX IS REPLACED BY AN ASTERISK (*) WHERE THE INSTRUMENT, VALVE OR EQUIPMENT IS PART OF A NUCLEAR SAFETY RELATED SYSTEM.
 4. THIS DRAWING HAS BEEN REDRAWN FROM GENERAL ELECTRIC CO. DRAWING NO 795632; REV 0 THIS IS A GENERAL ELECTRIC SYSTEM.

841150031

REVISION		REVISION		REVISION		REVISION		REVISION		REVISION		REVISION		REVISION		REVISION		REVISION		REVISION	
NO.	DATE	NO.	DATE	NO.	DATE	NO.	DATE	NO.	DATE	NO.	DATE	NO.	DATE	NO.	DATE	NO.	DATE	NO.	DATE	NO.	DATE

ONE STATE UTILITIES COMPANY
 RIVER BEND UNIT 1
 ENGINEERING P & I DIAGRAM
 SYSTEM 203
 LOW PRESSURE CORE SPRAY
 DRAWING NO. PID-27-5A
 SHEET NO. 0

228.211
 1052#V31

PDR RIDS

841150031

