



NO.	DATE	REVISIONS
1		REVISED PER ICP 80-1085 MT
2		REVISED PER ICP 80-1085 MT

FOR INFORMATION ONLY
 THIS DOCUMENT IS NOT CONTROLLED.
 VERIFY INFORMATION WITH A CONTROLLED DOCUMENT.

- 1. WORKING TO BE "IE" ALL
- 2. ORIGINAL WIRING TO BE "14 AWG SIS"
- 3. SEE WJG. E 532 FOR CABINET WIRING
- 4. EXERCISING CV2680 CAN ONLY OCCUR IN THE 75-100% OPEN RANGE.

REF. EFC TRIP MODULE E-304
 P11D M-206
 LOGIC M-404
 V/P 6000-M180-34
 E-317 (CV-2630, 2630)
 E-295 (CV-2617, 2627)

ARKANSAS POWER AND LIGHT COMPANY
 ARKANSAS NUCLEAR ONE
 UNIT 1

SCHEMATIC DIAGRAM
 STEAM GENERATOR
 ISOLATION CONTROL

DRAWING NO.	REV
E-315	SH 1 OF 5 2-1

8307260587

RIDS

8307260587

