

INFORMATION
THIS DOCUMENT IS
SUBJECT TO REVISION
WITHOUT NOTIFICATION
TO THE USER OF THIS
COPY

REFERENCE DRAWINGS

- 0-E-0105 ELECT. WIRING STANDARDS & SYMBOLS
- I-E-G089 CONTROL WIRING DIAGRAM 480V ESF. FDR. BKR. EIC3 TO MCC EIC3
- 2178D60 SCHEMATIC DIAGRAM BKR FILE NO E161X009 W.U.

NOTE:
THE RED (BKR POSITION) INDICATING LIGHT AT THE LC SHALL MONITOR THE TRIP COIL.

LOCATED AT 480V ESF LOAD CENTER EIC COMET. ID ELECT. EQUIP NO 3EIGIESGOEIC

TERA APERTURE CARD

NUCLEAR SAFETY RELATED CLASS 1E

PL PKG: 076 SUFF: 104 ACT: 581

NO	DATE	DESCRIPTION	BY	CHK	ENG	DES	DRG	PROJ	NO	DATE	DESCRIPTION	BY	CHK	ENG	DES	DRG	PROJ	NO	
B		REVISED PER ENG COMMENTS & ISSUED FOR USE	PM																
A		ISSUED FOR USE	RH	VT															

Brown & Root Inc.
ENGINEERS-CONSTRUCTORS
HOUSTON, TEXAS

SOUTH TEXAS PROJECT


DRAWING TITLE	CONTRACT NO	SCALE
ELECTRICAL	CR-0241	NONE
480V ESF. FDR. BKR. EIC3 TO MCC EIC3	DRAWING NO 4-E-16	
	I-E-4089-B	

INFORMATION () PRELIMINARY () REVIEW () USE () CONSTRUCTION



BROWN & ROOT INC.
MICROFILM SERVICES

MONDAY, FEB. 2 1981



RIDS

8112180280

