



This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and used on the customer's project subject to the customer's express agreement that they will not be reproduced, copied, loaned, altered, or used in any way without the express written consent of BECHTEL.

SIZE E
 SYSTEM HA

REF. NO.	REFERENCE DRAWING	BECHTEL VENDOR CODE
1	VENDOR LOGIC DIAGRAM	3665
2	P&ID	3665
3	LOGIC DIAGRAM MISC. ALARMS	3-108

- NOTES:
- ALL THE LOCAL ALARMS OF THE AMBIENT CHARCOAL TREATMENT SYSTEM PROVIDE A COMMON RECIRCULATION ALARM IN THE MAIN CONTROL ROOM.
 - SEAL AIR SUPPLIED TO STEMS OF ALL PROCESS AND DEAN PLUG VALVES, STEM PACKING GLAND CONNECTION IS 30 PSIG.
 - ALL THE INSTRUMENTS, VALVES AND EQUIPMENT ARE SUPPLIED BY KOCH PROCESS SYSTEMS EXCEPT FOR THOSE DENOTED BY *A WHICH ARE PROVIDED BY BECHTEL.
 - TYPE A COPPER TUBING REQUIRES COLD INSULATION.

PRO APERTURE CARD

BECHTEL SAN FRANCISCO			
PUBLIC SERVICE ELECTRIC AND GAS COMPANY HOPE CREEK GENERATING STATION			
GASEOUS RADWASTE AMBIENT CHARCOAL TREATMENT SYSTEM			
DATE	REVISION NO.	BY	CHK
1966	M-70-0	OF 3	1

RIDS

8307270081

