



SYSTEM HA	
REF. NO.	REFERENCE DRAWING
1	VENDOR LOGIC DIAGRAM

- NOTES:
- SEE NOTE 2 OF SH 1
 - ALL THE INSTRUMENTS, VALVES AND EQUIPMENT ARE SUPPLIED BY EACH PROCESS SYSTEM EXCEPT FOR THOSE PROVIDED BY OR WHICH ARE PROVIDED BY BECTEL
 - THIS INSTRUMENT APPEARS MORE THAN ONCE ON THIS P&ID
 - BE-4281 DE-4282, RR-223, DIS-4201, DIS-4227 ARE PROVIDED BY APCT
 - PE TO BE AS CLOSE TO Y246 AS POSSIBLE
 - DOP (DI-OCTYL-PHTHALATE) SMOKE TEST TAP FOR HEPA FILTER CARTRIDGE

PRC
APERTURE
CARD

DATE	BY	CHKD	APP'D

BECTEL
SAN FRANCISCO
PUBLIC SERVICE ELECTRIC AND GAS COMPANY
MOPE CREEK GENERATING STATION

P&ID
GASEOUS RADWASTE AMBIENT
CHARCOAL TREATMENT SYSTEM

NO. 10366 M-70-0 SH 2 OF 3

RIDS

8397270083

