

INFORMATION
THIS DOCUMENT IS
SUBJECT TO REVISION
WITHOUT NOTIFICATION
TO THE USER OF THIS
COPY

TERA
APERTURE
CARD


REFERENCE DRAWINGS
0-E-0105 ELECT. WIRING STANDARDS & SYMBOLS
1-E-6073 CONTROL WIRING DIAGRAM 480V ESF. LC EIA TIE BKR EIA1/EIA2
9178060 @ ELEM. DIAG. B & R FILE # EIGX009 WU

NOTE
1. THE RED (BKR. POSITION) INDICATING LIGHT AT THE LC SHALL MONITOR THE TRIP COIL.
LOCATED AT 480V ESF LOADCENTER EIA COMPT 2C.
ELECT. EQUIP NO 3EIGIESG0EIA

CS-LC

CONTACTS (HANDLE-END)	POSITION				USE
	PULL	TRIP	OFF	CLOSE	
1 0 ¹ -0 ²				X	CONT.
3 0 ¹ -0 ⁴	X	X			CONT.

X-DENOTES CONTACT CLOSED
WESTINGHOUSE TYPE W




NUCLEAR SAFETY RELATED
CLASS 1E

PL	PKG: 071	SUFF: 104	ACT: 581
DRAWING TITLE ELECTRICAL		CONTRACT NO	SCALE
ELEMENTARY DIAGRAM		CR-0241	NONE
480 VESF. LOADCENTER EIA TIE BKR. EIA1/EIA2		DRAWING NO	4-E-16
			1-E-4073-C

MICROFILMED JUL 1978

BROWN & ROOT INC.
MICROFILM SERVICES

MONDAY, FEB. 2 1981



INFORMATION PRELIMINARY REVIEW USE CONSTRUCTION

RIDS

8112180299

