



REFERENCE DRAWING	SYSTEM	DATE
1 ADMIN FACIL. CONTROL DIAGRAM	N-14-0	
2 ADMIN FACIL. CHILLED WATER DIAGRAM	N-13-0	

- NOTES:
1. ALL FLOOR PENETRATIONS REQUIRE FIRE DAMPERS
 2. DELETED
 3. ALL DUCTS ARE 5NK.
 4. THIS P&ID CONTAINS SYSTEMS OR PORTIONS OF SYSTEMS. 00-ADMIN. STATION BLDG. HVAC
 5. INDEX NUMBERS FOR OPERABLE DAMPERS ARE SHOWN ON M-74-0
 6. NO EQUIPMENT OR DUCTS ON THIS DRAWING ARE SEISMIC CATEGORY 1 OR 'O' LISTED.

PRO APERTURE CARD

NO.	DESCRIPTION	DATE	BY	CHKD.

BECHTEL
SAN FRANCISCO
PUBLIC SERVICE ELECTRIC AND GAS COMPANY
SOPE GREEN GENERATING STATION

P&ID
ADMINISTRATION FACILITY
AIR FLOW DIAGRAM

NO. 10885 M-80-0 5

11

11

8.5"

8.5"

11

17"

11

11

8.5"

8.5"

11

17"

RIDS

8307270113

