



This drawing and the notes it contains are the property of GEORGIA. They are loaned to you for your information only. They are not to be reproduced, copied, loaned, sold, or used in any way without the express written permission of GEORGIA.

- NOTES
- THIS PANEL CONTAINS SYSTEM CLASS E DIESEL AREA CLASS E PANEL ROOM AREA HVAC.
  - REPLACE LINES FOR DIFFERENT CLASS E CHANNELS MUST HAVE A MINIMUM 3 FT. SEPARATION.

TABLE 431  
ELECTRICAL UNIT METERS

UNIT NUMBER	TO WHICH
IAY 421	9566 A
IDV 421	9566 B
IDV 421	9566 D
IAY 422	9567 A
IDV 422	9567 B
IDV 422	9567 C
IDV 422	9567 D
IAY 425	9566 A
IDV 425	9566 B

TABLE 433  
BATTERY ROOM DUCT HEAT COILS (BRDC)

BATTERY ROOM	DUCT NO.	CLASS	TR. TC.	TR. TC.	TR. TC.	TR. TC.	TR. TC.
5614	IAY 423	C	9565 A	9565 B	9565 C	9565 D	9565 E
5609	IAY 425	D	9565 B	9565 C	9565 D	9565 E	9565 F

TABLE 434  
BATTERY ROOM DUCT HEAT COILS (BRDC)

BATTERY ROOM	DUCT NO.	TR. TC.	TR. TC.	TR. TC.	TR. TC.
5606	IAY 426	9566 A	9566 B	9566 C	9566 D
5627	IAY 428	9566 C	9566 D	9566 E	9566 F

PRC APERTURE CARD

DATE	BY	CHKD	APP'D
<b>SECRET</b>			
FOR OFFICIAL USE ONLY			
GROUP 1 EXCLUDED FROM AUTOMATIC DOWNGRADING AND DECLASSIFICATION			
EXEMPT FROM GDS, E.O. 11652			
EXEMPT FROM GDS, E.O. 12958			
EXEMPT FROM GDS, E.O. 13526			
EXEMPT FROM GDS, E.O. 13526			

RIDS

8307270151

