



INSERVICE INSPECTION

REVISIONS BLOCK

REV. NO.	DESCRIPTION	CHKD. DATE	CHKD. BY	APPROV. DATE
0	REL FOR CONST VN. 22026	12-17-79	AK	12-28-79
1	CHANGED ITEM NO. FOR VALV. ZNC 20	1-15-80	AK	1-22-80
2	CHANGE ITEM NO. ON VALVES ZNC 20 AND ZNC 253 C	2-19-80	AK	2-23-80
3	ADDED Q.A. Condition I	7-28-82	AK	7-28-82

FOR INFORMATION ONLY

SI APERTURE CARD

ITEM	SIZE	DES.	SPEC./GRADE	SPEC./GRADE	SCH./RATE	REMARKS
(I)		ZNC 253 C	9J-16			
(H)		ZNC III	9J-26			
(G)		ZNC 20	9J-16			
(F)		ZNC 19	9J-16			
(E)	1"	PIPE	SA312/TP304	SA376/TP304	160	SMLS
(D)	2"x1"	RED. INS.	SA182/F304	SA403/WP304	6000*	FS SW
(C)	2"	TEE	SA182/F304	SA403/WP304	6000*	FS SW
(B)	2"	90° ELL	SA182/F304	SA403/WP304	6000*	FS SW
(A)	2"	PIPE	SA312/TP304	SA376/TP304	160	SMLS

FOR INFORMATION

SIZE	RT	PT	PIPE	WELDS
< 2 1/2"	15			
3" - 6"				
8" - 12"				
14" - 20"				
> 20"				
TOTALS	15			
TOTAL RT WELDS		0		
TOTAL PT WELDS		15		

OR

BILL OF MATERIAL Q.A. Condition I

DUKE POWER COMPANY
McGUIRE NUCLEAR STATION

LAST WELD NO. 15 LAST FL. NO. NA

NUCLEAR SAFETY RELATED YES NO BUILDING: REACTOR ZONE: R-22

PIPE SPEC: 2501.1 SYS. SYMBOL: NC SEC. NO: NC-03 DRAWING NO: 2414-03-20-03,06 EL: 727'-1 13/16"

APPLICABLE CODE: ASME SECT. III CLASS: A ISO. NO: MCFI-2NC 95 REV: 3

PDR RIDS

803290343

