



△ THIS SYMBOL DENOTES MATERIAL THAT IS PART OF A PREASSEMBLED SECTION TO BE USED BY INSP. FOR FIT UP AND HEAT NO. CHECK ONLY

DUNGAN-PARKHILL, INC., CHARLOTTE 278

REVISIONS BLOCK

GRID	REV. NO.	DESCRIPTION	ORIG. DATE	CHGD. DATE	APPROV. DATE
	0	REL FOR CONST.	7-20-78	8-1-78	6-16-78
	1	ADDED "P" TO 2NI239, 2NI240 PRE ASSY SECTION	8-7-78	8-15-78	8-15-78
	2	ADDED Q.A. Condition I	9-12-82	7-14-82	7-14-82

FOR INFORMATION ONLY

SI APERTURE CARD

ITEM	SIZE	DES.	SPEC./GRADE	SPEC./GRADE	SCH./RATE	REMARKS
△ D	2"	PIPE	SA32 TP304	SA376 TP304	160	SMCS
△ C	2"	W/BOSS	SA182 F304	SA403 WP304	6000	FS SW
△ B		2NI 171	IN. 9J-4			
△ A	2"	F.CPLG.	SA182 F304	SA403 WP304	6000	FS SW

GR

LAST WELD NO. 4

DUKE POWER COMPANY  
McGUIRE NUCLEAR STATION

LAST FL. NO. NA

NUCLEAR SAFETY RELATED  YES  NO

BUILDING: REACTOR ZONE: R-23

PIPE SPEC: 2501.1 SYS. SYMBOL: NI SEC. NO: 17 DRAWING NO: MC2414-09.21-001 01 EL: 725'

APPLICABLE CODE: ASME SECTION III CLASS: A ISO. NO: MCFI-2NI34 REV: 2



8903300351

PDR RIDS

