

INSERVICE INSPECTION



NOTES
 1- ALL WELDS TO RECEIVE FULL INSPECTION.

REVISIONS BLOCK				
GRD	REV. NO.	DESCRIPTION	DATE	BY
	0	REL FOR CONST	1-20-59	WAW
	1	ADDED Q.A. Condition I	1-20-59	WAW

FOR INFORMATION ONLY

SI APERTURE CARD

ITEM	SIZE	DES.	SPEC./GRADE	SPEC./GRADE	SCH./RATE	REMARKS
(E)		ZNI124	IN. 90-4			
(D)		ZNI128	IN. 90-4			
(C)	2"	SP WELD BASS	SA182 F304	SA403 WP304	6000	FSSW
(A)	2"	90ELL	SA182 F304	SA403 WP304	6000	FSSW
(B)	2"	PIPE	SA312 TP304	SA376 TP304	160	SMS

BILL OF MATERIAL Q.A. Condition I			
LAST WELD NO.	DUKE POWER COMPANY	LAST FL. NO.	
12	McGUIRE NUCLEAR STATION	N/A	
NUCLEAR SAFETY RELATED		YES	NO
PIPE SPEC:	SYS. SYMBOL	<input type="checkbox"/>	<input type="checkbox"/>
2501.1	NI 30	BUILDING:	ZONE:
APPLICABLE CODE:	CLASS:	ISO. NO.:	REV.:
ASME SECTION III	A	McFI-2NI109	1

894339/329

PDR RIDS

