



* WELD REQUIRE FULL INSPECTIONS!
 ● THESE WELDS WERE MADE IN THE PIPE FAB SHOP

| REVISIONS BLOCK | | | | | |
|-----------------|----------|---|---------|-----|-----------|
| GRID | REV. NO. | DESCRIPTION | DATE | BY | APP. DATE |
| | 0 | REL FOR CONSTR. | 1-22-79 | ELM | 1-22-79 |
| | 1 | ADDED CONT. AND DELETED DRAWING | 1-15-79 | ELM | 1-15-79 |
| | 2 | CHANGED SPEC ON PART ADDED TO WELD NIZFWIII-6 | 2-17-79 | ELM | 2-22-79 |
| | 3 | ADDED NOTE SHOWING WELDS MADE IN THE FAB SHOP | 2-20-79 | ELM | 2-23-79 |
| | 4 | ADDED Q.A. CONDITION I | 2-2-79 | ELM | 2-13-79 |

FOR INFORMATION ONLY

SI APERTURI CARD

| (E) | 2 NI 193 B | 4J-9 | | | | |
|------|--------------------|---------------|---------------|-------------|-----------|---------|
| (E) | 2 NI 216 | 9J-8 | | | | |
| (C) | 3/4" PIPE | SA-376 TP 304 | SA-312 TP 304 | 160 | SMLS | |
| (C) | 3/4" SP. WELD BOSS | SA-192 F 304 | SA-403 WP 304 | 6000 | FS SW | |
| (B) | 1 1/2" CONC. RED. | SA-403 WP 316 | | 140 | SMLS | |
| (A) | 12" PIPE | SA-376 TP 316 | | 140 | SMLS | |
| ITEM | SIZE | DES. | SPEC./GRADE | SPEC./GRADE | SCH./RATE | REMARKS |

OR

BILL OF MATERIAL Q.A. Condition I

| | | |
|------------------------------|---|----------------------------------|
| LAST WELD NO. 60 | DUKE POWER COMPANY McGUIRE NUCLEAR STATION | LAST FL. NO. NA |
| NUCLEAR SAFETY RELATED | | BUILDING: A-3 |
| PIPE SPEC: 2501.2 | SYS. SYMBOL: SAFETY INJECTION SYS | SEC. NO.: 32 |
| APPLICABLE CODE: ASME III | CLASS: B | DRAWING NO.: MC 2414-09.42-00 |
| | ISO. NO.: MCFI-2NI III | EL: 733'-0" |
| | | REV: 4 |

890330032

PDR RIDS

