



LOOP B HX B1E201 INLET VALVE HV-2491B
CLASS 1E CHANNEL B

'CROSS REFERENCE' TABLE

SERVICE	HX NO.	VALVE NO.	CONTROL SW. CONTROL RW.	RSP	POSITION SW. (NOTE 1 SHT 4)	TORQUE SW. (NOTE 1 SHT 4)	LOGIC CAB.	CC	RSP	TC	CLASS 1E CHANNEL	CHT NO.	SACS PUMP	RSP EMER. STOP	MCC
LOOP B	B1E201	HV 2491B	HS 2491E1	HS 2491B2	ZS 2491B	WS 2491B	BC652	C-651A	C-399	BC657	B	2	BP210 (03/08/03)	03/08/03	B222
HX INLET	B2E201	HV 2491B	HS 2491E1	HS 2491B2	ZS 2491B	WS 2491B	DC652	C-651A	C-399	DC657	D	4	DP210 (03/08/03)	03/08/03	B242

NOTES:
1. RESETS FOLLOWING RESTORATION OF BUS POWER.
2. SEE SHT. 4 FOR PICTORIAL OF SWITCH LIGHTS

PRO APERTURE CARD

NO.	DATE	REVISIONS	BY	CHKD	DESIGN	INSTR	APPR
1	1/2/72	DESIGN FREEZE ISSUE	JF	JP	JM		
2	2/23/72	REVISED BAILEY INTERFACE AND AS NOTED	CL	CL	CL		
3	7/7/72	INC. DCN #1	CL	CL	CL		
4	1/5/73	REVISED AS NOTED	CL	CL	CL		
5	3/6/77	ISSUED FOR CONSTRUCTION	CL	CL	CL		

SCALE: NONE

DESIGNED: I.J.L. DRAWN: RCG

BECHTEL
SAN FRANCISCO

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
HOPE CREEK GENERATING STATION

LOGIC DIAGRAM
SAFETY AUXILIARIES COOLING
SACS LOOP B HX INLET VALVES

JOB NO.	DRAWING NO.	REV.
10255	J-11-0	SHT 13

10776 (04/11/00) - (350 250)

S/U - EG

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, nor used except the limited and private use permitted by any written consent given by the lender to the borrower.

RIDS

8307270374

