



- NOTES:**
- 120 VAC POWER IS FROM MAIN OIL PUMP STARTER.
 - 120 VAC IS FROM REMOTE CONTROL PANELS 100190 AND 100190 RESPECTIVELY.
 - REMOTE CONTROL PANELS 100190 AND 100190 ARE SUPPLIED AND WIRED BY COMPRESSOR VENDOR. FOR INTERNAL WIRINGS SEE VENDOR PRINT 10855-M50-14.
 - ⊙ DENOTES FIELD ACCESSIBLE TERMINAL NUMBER ON VENDOR PANEL.
 - ALL EQUIPMENT SHOWN ON THIS DRAWING IS NON-Q LISTED.
 - NUMBERS SHOWN IN PARENTHESES DENOTE VENDOR DEVICE NUMBERS.
 - SEE SHEET 2 OF THIS DWG FOR REMAINDER OF HAND SWITCH LAYOUT.
 - FOR AUTOMATIC START OF MAIN OIL PUMP, SEE VENDOR PRINT 10855-M50-14.
 - WIRING BETWEEN CONTROL PANEL AND MACHINE MOUNTED DEVICES IS BY VENDOR.

CROSS REFERENCE TABLE

COMPRESSOR NO.	MAIN/AUX OIL PUMP WTR VALVE HS	LOGIC CAB. NO.	REMOTE CONTROL PNL.	TC	MCC	CXT. NO.	VB	MCC. FOR FOR MOP
10K107	1-HS-7644-1 1-HS-7644-2	100659	100190	100659	100113103	1	100650A	100113
60K107	0-HS-7644-1 0-HS-7644-2	100659	100190	100659	008186063	2	100650A	008186

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned to you for the purpose of construction. They are not to be reproduced, copied, or used in any way without the express written permission of BECHTEL.

PT APERTURE CARD

NO.	DATE	BY	REVISION
1			ISSUED FOR CONSTRUCTION

BECHTEL
SAN FRANCISCO

WORLD WIDE ELECTRIC AND GAS COMPANY
GROUP ENGINEERING DIVISION

STATION AIR COMPRESSOR 10K107

DATE: H-15-80

S/U - KR

RIDS

8307270498

