



762E433AA
 1 C 2000
 C 000MM LVE P
 RETRACED WITH C
 CHK BY: C
 15/10/85

- NOTES
- EXCEPT AT POINTS OF CONNECTION WITH NED SUPPLIED EQUIPMENT OR PIPING, THE PIPING DESIGNER SHALL SIZE PIPES IN CONFORMANCE WITH THE SLS SYSTEM DESIGN SPECIFICATION.
 - INSTRUMENT PIPING AND VALVING SHALL BE INSTALLED IN ACCORDANCE WITH SUPPL. DOC 2.
 - PIPING HIGH POINT VENTS & LOW POINT DRAINS ARE TO BE ADDED AT ALL SUCH HIGH OR LOW POINTS NOT SERVED BY EQUIPMENT VENTS AND DRAINS.
 - ALL EQUIPMENT AND INSTRUMENTS ARE PREFIXED BY C41, UNLESS OTHERWISE NOTED.
 - DRAINS SHOULD BE ROUTED TO A COMMON COLLECTION AREA. MANHOLES OF DRAIN LINES, WHERE PRACTICAL, IS PERMISSIBLE. SPACE SHALL BE PROVIDED IN COLLECTION AREA FOR REMOVABLE TYPE CONTAINERS, SUCH AS 55 GALLON DRUMS.
 - THE ELEVATION OF THE DEMINERALIZER WATER AND PLANT AIR SUPPLY LINES SHALL BE ABOVE THE TOP OF THE STORAGE TANK.
 - FOR LOCATION AND IDENTIFICATION OF INSTRUMENTS, SEE INSTRUMENT DATA SHEET LISTED IN MPL FOR EACH INSTRUMENT.
 - FLUSHING CONNECTIONS (SUPPLY AND DRAIN) SHALL BE LOCATED TO ALLOW FOR MAXIMUM SYSTEM FLUSH AND DRAIN AND SHALL BE PROVIDED IN ACCORDANCE WITH SUPPL. DOC 3. TEMPORARY STRAINER SCREENS SHALL BE PROVIDED ON THE SUCTION SIDE OF ALL PUMPS IN ACCORDANCE WITH SUPPL. DOC 3.
 - ORIENT PRESSURE INDICATOR (PI) SO THAT IT CAN BE READ FROM VALVE F015 LOCATION.
 - ZONE INSIDE INTERFACE ARROW IS FOR RELAY PROTECTION SYSTEM AND ZONE OUTSIDE INTERFACE ARROW IS FOR SOLID STATE PROTECTION SYSTEM.

- SUPPLEMENTAL DOCUMENTS UNDER THE FOLLOWING IDENTIFIERS ARE TO BE USED IN CONJUNCTION WITH THIS DRAWING:
- | IDENTIFIER | REFERENCE DESIGNATOR |
|---|----------------------|
| 1. NUCLEAR BOILER SYSTEM P&ID | B2-100 |
| 2. PROCESS INSTRUMENTATION | A52-4070 |
| 3. CLEANING OF PIPING & EQUIPMENT | A2-4140 |
| 4. SLC SYSTEM F&D | C41-1030 |
| 5. SLC SYSTEM I&S | C41-3050 |
| 6. PIPING & INSTRUMENT SYMBOLS DWG | A42-1010 |
| 7. PRESSURE INTEGRITY OF NUCLEAR COMPONENTS | A62-4033 |

LEGEND
 ▲ ERIS POINT IDENTIFICATION

TI
 APERTURE
 CARD

EQUIPMENT CLASS CODE		MPL NO. C41-1000	
REPORTING TO SAFETY	YES/NO	CLASS 1	YES/NO
THIS ITEM IS OR CONTAINS A SAFETY RELATED ITEM	YES/NO	NUCLEAR SAFETY RELATED	YES/NO
DATE	7/2/84	GENERAL ELECTRIC	
DESIGNED BY	M. MONTOYA	REV.	DEPT.
DRAWN BY	A.B. ROQUE	LOC.	SAN JOSE
CHECKED BY	F.M. HERRERO	P&ID	
APPROVED BY	A. ALAM	STANDBY LIQUID CONTROL SYSTEM	
DATE	27/02/84	762E433AA	
SCALE	1:1	MAR 2 1984	
UNLESS OTHERWISE SPECIFIED		762E433AA	
2 PLACE DECIMALS + FRACTIONS +			
3 PLACE DECIMALS + ANGLES +			
IGS	2	R	1

PDR RIDS

225

8412180072

To be coded

