



NOTES:

1. WAVE SLOPE REQUIREMENTS.
2. FITTINGS, TUBINGS, AND VALVES DESIGNATED ON THIS DETAIL BY CLASSIFICATION 4S OF THE FITTINGS CLASSIFICATION LIST ARE SAFETY CLASS. SUBSTITUTES FROM OTHER CLASSIFICATIONS ARE NOT PERMITTED. NUCLEAR SAFETY RELATED EXCLUSIONS
 - a) NONE
1. FITTINGS, TUBINGS, PIPING, & VALVES (NOT PART OF A SAFETY RELATED PIPING SYSTEM, ETC.)
 - a) NONE
2. INSTRUMENTS (DO NOT SERVE A SAFETY FUNCTION)
 - a) 2NP65200, 2NP65200
 - b) 2NP65210, 2NP65210

AS - BUILT
 DATE 4-9-81

3 <

QA CONDITION I

NUCLEAR SAFETY RELATED

(EXCEPT AS EXCLUDED ABOVE)

FUNCTIONAL DESCRIPTION: (FOR A APPLIES TO B)

2NP65200 AND 2NP65200 MONITOR RHR PUMP "A" DISCHARGE PRESSURE
 2NP65200 PROVIDES LOCAL INDICATION. 2NP65200 IS FOR RESPONSE
 TIME TEST AND ALARMS ON INCREASING PRESSURE.

| | | | | | | | |
|-------|------------------------|------|------|--|-------------|------|----------|
| | | | | DUKE POWER COMPANY MCGUIRE NUCLEAR STATION - UNIT 2 | | | |
| | | | | INSTRUMENT DETAIL RHR PUMP DISCHARGE PRESSURE | | | |
| 3 | Added "AS-BUILT" stamp | JPA | JPA | 4-9-81 | N/A | N/A | N/A |
| 2. | Rev. Note 2. | CPT | CW | 8-27-78 | N/R | N/R | N/R |
| 1 | REV. NOTE 1 | CPT | MP | 8-27-78 | N/R | N/R | N/R |
| ORIG. | DEL. FOR CONTR. | RD | MP | 1-29-78 | N/R | N/R | N/R |
| NO. | REVISIONS | CHKD | APPR | DATE | CIVIL | ELC. | WFGH. |
| | | | | | INSPECTED | | |
| | | | | DWG. NO. | MC-2499-ND7 | | REV 3 |

FOR INFORMATION
 ONLY

CL 2 Hydro SHG

8904030473

PDR RIDS

