



MARK NUMBERS

- 2NIFE5000
- 2NIFE5010
- 2NIFE5020
- 2NIFE5030
- 2NIFE5460
- 2NIFE5470
- 2NIFE5480
- 2NIFE5490
- 2NIFE5500
- 2NIFE5510
- 2NIFE5520
- 2NIFE5530

EXCLUDED SAFETY RELATED EXCLUSIONS

1. Fittings, Tubings, Piping, & Valves (Not part of a Safety Related Piping System, Etc.)
 - a) None
2. Instruments (Do not serve a Safety Function)
 - a) N/A

NOTES:

1. Flow metering orifice is to verify flow during pre-operational test, calibration, and balance.
2. Fittings, tubings, and valves designated on this detail by classification 1s of the Fittings Classification List are safety class. Substitutes from other classifications are not permitted.

7-21-81

NUCLEAR SAFETY RELATED
(EXCEPT AS EXCLUDED ABOVE)

				DUKE POWER COMPANY	
				MCGUIRE NUCLEAR STATION UNIT 2	
				INSTRUMENT DETAIL	
				NI SYSTEM FLOW ELEMENTS FOR PRE-OPERATIONAL TEST	
3	REV. PER VN# 27 021	W. J. ROSS	12/21/81	INSPECTED	DATE 12/21/81
2	Added "AS-BUILT" Stamp	W. J. ROSS	11/21/81	INSPECTED	DATE 11/21/81
1	Revised as Noted	W. J. ROSS	10/21/81	INSPECTED	DATE 10/21/81
	Rel. for Constr.	W. J. ROSS	07/21/81	INSPECTED	DATE 07/21/81
NO.	REVISIONS	CHKD	APPR	DATE	CIVIL, ELRC, MECH
					INSPECTED
				DWG. NO.	MC-2499-NI41
					REV 3

FOR INFORMATION ONLY

CL-2499 Ro SHZ

SI
APERTURE
CARD

8904030480

PDR RIDS

