



LF = 298'

POOR ORIGINAL

- NOTES:**
1. ALL PIPING TO BE FABRICATED AND INSTALLED IN ACCORDANCE WITH SPECIFICATIONS 7220-200
 2. FOR MATERIAL DESCRIPTIONS, SEE THE GENERAL NOTES OF THE PIPING CLASS SHEETS, W-7
 3. FOR PIPING AND RESTRAINT DESIGNATIONS, SEE DWG. SH-633-3
 4. FOR ELEVATION LIST, SEE SHEET
 5. FOR DIMENSIONS, REFER TO THE ISOMETRIC DRAWING
 6. ALL PIPING HAS BEEN 1/2\"/>
 - 7. FOR PIPING SYSTEM COMPARTMENT IDENTIFICATION, SEE AREA KEY
 - 8. FOR BRACKETING SCHEDULE, SEE DWG. W-444
 - 9. PIPE BENDS UNLESS OTHERWISE NOTED HAVE A MINIMUM CENTERLINE RADIUS OF FIVE (5) TIMES THE NOMINAL PIPE DIAMETER
 - 10. FOR PIPING AND RESTRAINT SYMBOLS, SEE DWG. SH-633-3
 - 11. FIELD WELD SYMBOLS, REFER TO THE WELDING SYMBOLS AND WELDING (AWS) CODE
 - 12. FOR SIZES AND WEIGHTS OF WELLS, SEE THE WELLS AND WELLS SYMBOLS SHEET, W-12
 - 13. ALL PIPING TO BE FIELD WELDED, UNLESS OTHERWISE NOTED, SHALL BE WELDED TO THE WELLS, UNLESS OTHERWISE NOTED
 - 14. INDICATES REACTOR WELDING, REFER TO WALL PENETRATION
 - 15. INDICATES FLANGE IN WALL PENETRATION
 - 16. HANGERS INDICATED ON THIS ISD ARE BECHTEL DESIGNED HANGERS, FOR ALL OTHER HANGERS, REFER TO THIS DWG. SEE GRINNELL HANGER DWG. SH-633-6

REV. 01	REV. TO REFLECT REV. 14 OF SH-633	REV. 01	REV. 01
REV. 02	REV. TO REFLECT REV. 13 OF SH-633	REV. 02	REV. 02
REV. 03	UPDATED TO REFLECT REV. 12 OF SH-633	REV. 03	REV. 03
REV. 04	REVISED FOR LOCAL CHANGES	REV. 04	REV. 04
REV. 05	DATA PLS. 8314 S41 ADDED FOR REV. 05	REV. 05	REV. 05
REV. 06	UPDATED TO REFLECT REV. 11 OF SH-633	REV. 06	REV. 06
REV. 07	REVISED TO REFLECT REV. 10 OF SH-633	REV. 07	REV. 07
REV. 08	ISSUED FOR SUPPORT Pkg. P-8	REV. 08	REV. 08
REV. 09	REVISED FOR SUPPORT Pkg. P-8	REV. 09	REV. 09
REV. 10	REVISED FOR SUPPORT Pkg. P-8	REV. 10	REV. 10

BECHTEL		
4800 AVENUE HIGHWAY		
MIDLAND PLANT UNITS 1 & 2		
CONSUMERS POWER COMPANY		
HANGER ISOMETRIC		
AUXILIARY FEEDWATER		
DISCHARGE SYSTEM UNIT - 1		
JOB NO.	DRAWING NO.	REV.
7220	H-633 SH.6 (Q)	5

30X

TERA APERTURE CARD

I certify that the image contained on this frame was made in the normal and regular course of business on the date stated herein and that it is an accurate reproduction of the document submitted to the printer.

8.5"
11"
17"

8.5"
11"
17"

RIPS

8112220384

