



POOR ORIGINAL

30X

- NOTES:
1. DETERMINED WYE STRAINERS ARE PROVIDED BY DEMINERALIZER VENDOR ON NO. 7220-M-80.
 2. SERVICE AIR TO BE PIPED TO THE LOWEST HEADER. CONNECTIONS TO THESE PLANNERS TO BE CLOSED EXCEPT WHEN AIR IS REQUIRED.
 3. LINES P-CHCD-003 AND 006 HAVE BEEN PROVIDED TO ENABLE OPERATOR TO DETECT WATER IN THE VENT LINE AND SHOULD BE LOCATED IN A READILY ACCESSIBLE LOCATION.

NO.	DATE	REVISION	BY	CHKD.
1		REVISED AS INDICATED IN INCORPORATED DESIGN REVISIONS AND IN CIRCLES 15		
2		ISSUED FOR CONSTRUCTION THIS DRAWING IS TO BE COMPLETELY REDRAWN, REVISIONS TO BE COMPLETELY REDRAWN, REVISIONS TO BE COMPLETELY REDRAWN, REVISIONS TO BE COMPLETELY REDRAWN		

BECHTEL ANN ARBOR, MICHIGAN		
MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY		
PIPING AND INSTRUMENT DIAGRAM BORON RECOVERY UNIT 1 & 2		
JOB NO.	DRAWING NO.	REV.
7220	M-408 SH2B	2

TERA APERTURE CARD

8.5" 11" 17" (vertical scale on left)

8.5" 11" 17" (vertical scale on right)

RIDS

8112230121

