



TABLE I

ALARM FUNCTION	INITIATING DEVICE	DEVICE LOCATION	TYPE OF ALARM
TURBINE BRG OIL PRESS LOW	PS -	LOCAL	LOW
TURBINE TRIP	LIMIT SWITCH	E41-COGE	N/A
HPCI FLOW LOW	PIS-N651	CR	LOW
VACUUM TANK PRESSURE LOW	PSL -	LOCAL	LOW

TABLE II

ACTUATING DEVICE	TRIP FUNCTION	COLOR
SEE VPE REF B IDENTIFICATION OF ACTUATING DEVICES	TURBINE GENERATOR VALVE OPEN	RED GREEN
	TURBINE GENERATOR VALVE CLOSED	RED GREEN
	STOP VALVE OPEN	RED GREEN
	STOP VALVE CLOSED	RED GREEN

3-17-72

CC/AD DRAWING REVIEW PERMISSIVE AFTER IS SE TIME DELAY

COMMENTS AS CHECKED BELOW

FORWARDED BY: [Signature] DATE: 3/14/72

REVIEWED BY: [Signature] DATE: 3/14/72

JOB NO. 10880

BECHTEL POWER CORPORATION

SAN FRANCISCO

P.R.O. APERTURE CARD

1 E41 1030 64 6 1

RIDS

8307280/52

