



This drawing and the design it covers are the property of BEI/TEL. They are hereby loaned and on the borrower's express agreement that they will not be reproduced, copied, copied, duplicated, or used except in the limited way and precise use permitted by any written consent given by the borrower.

REV.	REV. REF. CHG. NO.	REASON FOR CHG.	DATE	BY	CHK.	APP.
4	1622-01	REV. REF. CHG. NO. 1622-01	11/11/81	...	...	...
3	1128-10	REV. SCHEDULE CHANGE TABLE	...	...	...	...
0	...	ISSUED FOR CONSTRUCTION	...	...	...	...

- DEVICES:**
- 186 : ELECTRICAL RESET & LOCKOUT RELAY (E-7813)
  - 151X : OVERCURRENT ALARM RELAY (18-315)
  - 162-1/TDE : AGASTAY TIME DELAY RELAY 7012 PD
  - 5X-1 : STATUS DISPLAY AUX RELAY GE TYPE H4A
  - LOP/ECCAS-588 : LOSS OF OFFSITE POWER/EMERGENCY CORE CLR. ACTUATION SYS-SEQUENCER (STEP 4-10 SEC)
  - FU : FUSE (CHASE SHANNUT A2K30)

SPARE COMPONENT COOLING WATER PUMP OP-73  
 SCHEME 18A0608  
 SU DESIG O-66A

**POOR ORIGINAL**  
**TERA APERTURE CARD**

BEI/TEL ANN ARBOR, MICHIGAN		
MIDLAND PLANT UNITS 1 & 2 CONSUMERS POWER COMPANY		
SCHEMATIC DIAGRAM SPARE COMPONENT COOLING WTR PUMP		
JOB NO.	DRAWING NO.	REV.
7220	E-206(Q) SHE 4	4

**16X**

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to reprographics.

6-26-81 R. Caselle  
 DATE CAMERA OPERATOR SUPERVISOR OF REPROGRAPHICS

G-1348

11  
8.5  
17

11  
8.5  
17



RIDS

8112230422

