



PIPES	(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)
O.D. (IN.)	6.815	6.435	4.500	3.500	3.000	2.000	1.500	1.000
WALL THK. (IN.)	0.1875	0.1875	0.1875	0.1875	0.1875	0.1875	0.1875	0.1875
SCHEDULE	100	100	100	100	100	100	100	100
MATERIAL	304	304	304	304	304	304	304	304
SPEC.	44B	44B	44B	44B	44B	44B	44B	44B
TOTAL UNIT WT. (LBS.)	54.400	54.400	54.400	54.400	54.400	54.400	54.400	54.400

VALVES OR FITTINGS	(J)	(K)	(L)
VALVE NO.	215	220	225
FITTING	230	235	240
O.D. (IN.)	2.000	1.500	1.000
WALL THK. (IN.)	0.1875	0.1875	0.1875
LENGTH (FT.)	4.000	3.000	2.000
MATERIAL	304	304	304
SPEC.	44B	44B	44B
TOTAL UNIT WT. (LBS.)	375.700	290.200	177.700

SPEC.	44B
TEMP (HOT)	680°F
TEMP (COLD)	104°F
PRESSURE	2485

- NOTES**
1. THIS DRAWING IS A FAITHFUL REPRODUCTION OF PRESS. DRAWING SET PCL, REVISION 2 DATED 7/17/98 AND ALSO INCLUDES ADDITIONAL INFORMATION DEVELOPED BY IMPELL CORPORATION.
  2. ALL DIMENSIONS ARE IN FEET UNLESS OTHERWISE NOTED.
  3. (B) BRANCH  
(F) FORGED TEE  
(R) REINFORCED PAD
  4. FOR LEGEND OF SYMBOLS SEE DWG. 1426.02 SH 2 OF 2.

SI APERTURE CARD  
8907190142

ATTACHMENT 3  
SHEET 3 of 4  
QUESTION 14

REV.	DATE	DESCRIPTION	BY	CHK'D.	APPV.
0	7/14/98	ADDED NODE POINTS	AS	ASF	AS

SCALE:      DESIGN:      DRAWN:

**IMPELL CORPORATION**

**PUBLIC SERVICE ELECTRIC & GAS COMPANY**  
SALEM NUCLEAR GENERATION STATION - UNIT 2  
**PRESSURIZER CHANGE LINE**

JOB NO.	DRAWING NO.	REV.
0140-096	1426.01	0



PDR RIDS

8907190142

