

This drawing and the design it covers are the property of BECHTEL. They are merely loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, nor used except in the limited way and private use permitted by any written consent given by the lender to the borrower.



1. CONTRACTS OPEN ON CONDITION STATED.
2. PANEL 00C531 IS SUPPLIED & WIRED BY DIESEL FIRE
PUMP VENDOR. FOR INTERNAL WIRING SEE VENDOR PRINT
10050-1950-32
3. PANEL 00C530 IS SUPPLIED & WIRED BY MOTOR FIRE
PUMP VENDOR. FOR INTERNAL WIRING SEE VENDOR PRINT
10050-1950-36

PRC
APERTURE
CARD

REVISED TO INCORPORATE MULTIPLIER 5.375 IN	24	34	25	12
REVISED TO REFLECT AS-BUILT INSTALL. A 5000 PSI RATED RISER	25	34	25	12
REVISED TO REFLECT AS-BUILT CONTENT WAS ON SHT. 4	26	34	25	12
DATE	BY	CHKD	DESIGN QTY	FIELD CORR APPR
02/23/86	DAVIDSON	FLP	CRAN	REG

BECHTEL
SAN FRANCISCO

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
MOOSE CREEK GENERATING STATION
NOS. 1 & 2 UNITS

LOGIC DIAGRAM
FIRE PROTECTION - FIRE WATER
FIRE PUMP ALARMS UNIT 1

 JOB NO. **10856** DRAWING NO. **H-22-0** SHT **9** REV. **2**

RIDS

8308089265

