


9	12/11/01	REDAUN ADDED INTERIM THRU 01/01/02	800	PH	47	QMC	304/142
—		1 DELETED CHANGES COVERED BY IDSU					
0	8-16-77	ISSUED FOR CONSTRUCTION	PRP	OLK	GHL	OLK	LHC/MU
	8/15	ENTIRE		OL		OLK	

NOTES.

2. CABLES 1NA0307A & 2NA0309A WERE  
ORIGINALLY ISSUED FOR CONSTRUCTION  
ON E-401 SH. 78 AS QNSP017A & G  
RESPECTIVELY.
3. SHORTING PINS MIGHT HAVE POOR MECH.  
INTEGRITY. THEREFORE PERMANENT JUMPER  
IS INSTALLED IN PARALLEL TO THE  
SHORTING PIN.


REFERENCES:

LOGIC DIAGRAM J-889  
V.P. E-205-260,261,274,275,276,281,  
327,328,343,344,347,351,384,393

BECHTEL  
ANN ARBOR, MICHIGAN

MIDLAND PLANT UNITS 1 & 2  
CONSOLIDATED POWER COMPANY

SCHEMATIC DIAGRAM  
4160-480V STATION POWER  
TRANSFORMER FEEDER BREAKERS

	JOB NO.	DRAWING NO.	REV.
	7220	E-76(Q) SH. 1	9

CERTIFICATE OF MICROFILMING

"I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to the contractor for filming, by Bechtel Power Corporation."

APERTURE  
CARD

12-29-81 Newlin S. Crockett  
Date Camera Operator Contractor's Sub'gr.



RIDS

803090354

