



- NOTES**
- FOR GENERAL NOTES, NOTES AND REFERENCE DRAWINGS SEE DWG. C-243
  - CONCRETE SHALL BE 4000 p.s.i. (F) UNQ.
  - ALLOWABLE FLOOD LIVE LOAD = 350 p.s.f.
  - FOR ADDITIONAL PENETRATIONS SEE PLANT DESIGN DRAWINGS 'A'-SERIES WHERE CONFLICTS EXIST. 'A'-DRAWINGS SHALL GOVERN.
  - STAINLESS STEEL LINER PLATE & NECESSARY BRACES (EXCEPT H.R. DRAWING) SHALL BE PROVIDED UNLESS CONTRACT SPECIFICATIONS OR SPECIFICATION 8550 C-10 & C-11 SHALL BE INSTALLED BY BECHTEL FIELD.
  - FOR HATCH DETAILS SEE DWG. C-512
  - FIELD HAS THE OPTION TO INTERCHANGE SECT. 'A' AND 'K'.
  - ALL STRUCTURAL & EMBEDDED STEEL SHALL CONFORM TO ASTM-A572-10, UNQ.

REFERENCE DWG'S.		REFERENCE DWG'S.	
BECHTEL NO.	PL. NO.	BECHTEL NO.	PL. NO.
C-145	E-105213 SH2	C-955	E-106782
C-146	E-105213 SH1	C-023	E-105899 SH1
C-243	E-105266	C-996	E-105773
C-244	E-104249	C-312	E-105897
C-251	E-105274 SH1	C-319	E-105320
C-267	E-105294	C-1099	E-105860
C-272	E-105285 SH1		
C-255	E-105274 SH2		
C-271	E-105298 SH1		

NO.	DESCRIPTION	DATE	BY	CHKD.	APP'D.
1	ISSUED FOR CONSTRUCTION	10/1/58	J. KOZLER		
2	ISSUED FOR REINFORCEMENT FABRICATION	10/1/58	J. KOZLER		
3	ISSUED FOR CLIENT REVIEW	10/1/58	J. KOZLER		

**PENNSYLVANIA POWER & LIGHT COMPANY**  
 ALLENTOWN, PENNSYLVANIA  
 SUSQUEHANNA STEAM ELECTRIC STATION - UNIT 1 UNIT 2

BECHTEL - SAN FRANCISCO

**REACTOR BUILDING UNIT 1  
 FLOOR PLAN  
 ELEVATION 818'-1" AREA 28**

JOB NO. 8856 DRAWING NO. C-245 REV. 11

DATE 10/1/58 DESIGNED / KOZLER DRAWN / ANELLO

SCALE 3/8" = 1'-0"

801210070

This drawing and the design it shows are the property of BECHTEL. They are hereby loaned to you under license and your use is restricted to the project and site shown. No part of this drawing may be reproduced, copied, loaned, exhibited, or used for any other project without express permission by the holder of this license.

RIDS-PDR

8012160070

