



- NOTES**
- FOR GENERAL NOTES, NOTES AND REFERENCE DRAWINGS SEE DWG. C-103 & C-801 RESPECTIVELY.
 - CONCRETE SHALL BE 4,000-PSI (f) U.N.O.
 - ALLOWABLE FLOOR LINE LOAD = 950 P/F.
 - FOR STRUCTURAL STEEL SEE DWG. C-314, C-331, & C-322.
 - FOR ADDITIONAL PENETRATIONS SEE PLUMBING DESIGN X-SERIES DRAWINGS WHERE CONFLICTS EXIST X-DWG'S SHALL GOVERN.

REFERENCE DWG'S.		REFERENCE DWG'S.	
BECHTEL NO.	PL. NO.	BECHTEL NO.	PL. NO.
C-244	E-105274	C-249	E-105276
C-248	E-105271	C-103	E-105199-1
C-267	E-105264	C-801	E-105598
C-261	E-105274-5	C-314	E-105321
C-249	E-105272	C-321	E-105326
C-720	E-105621	C-322	E-105329
C-192	E-105235	C-255	E-105548
		C-985	E-105274-5

NO.	DESCRIPTION	DATE	BY	CHKD.
1	ISSUED FOR CONSTRUCTION	11/15/52	J.W.	J.W.
2	ISSUED FOR FABRICATION OF REINFORCING STEEL	11/15/52	J.W.	J.W.
3	ISSUED FOR FABRICATION OF REINFORCING STEEL	11/15/52	J.W.	J.W.

PENNSYLVANIA POWER & LIGHT COMPANY
 ALLIANCE, PENNSYLVANIA
 SUSQUEHANNA STEAM ELECTRIC STATION - UNIT 2, UNIT 3

BECHTEL - SAN FRANCISCO

REACTOR BUILDING UNIT 2 FLOOR PLAN ELEVATION 818-1 AREA 30

JOB NO. 8856 DRAWING NO. C-247 REV. G

E-105270

REFERENCE DRAWINGS:
 FOR ARCHITECTURAL FLOOR PLAN SEE DWG. A-17
 FOR STAIR DETAIL SEE DWG. A-147 & A-148
 FOR EQUIPMENT LOCATION SEE DWG. M-256
 FOR PLUMBING & DRAINAGE SEE DWG. P-30-7, P-32-7, P-33-7, P-34-7
 FOR HEATING & VENTILATION SEE DWG. V-30-7, V-32-7, V-33-7, V-34-7
 FOR EMBEDDED ELECTRICAL ITEMS SEE ELECTRICAL DWG'S

This drawing and the design it covers are the property of BECHTEL. They are hereby loaned to the borrower's expense agreement that they will not be reproduced, copied, loaned, sold, or otherwise disposed of in any manner without the written consent of BECHTEL.

RIDS - PDR

8012160100

