



DIAPHRAGM (E) & SECURITY GRATING (M) - SEE NOTE BELOW TYPICAL PLACES, SEE DET. (A-205)

NOTE: WELD 2x3 BY 3/8 FILLLET WELD ALL AROUND FIELD OF TYP. TO USE BRUNTED ALUM. STEEL IN LIEU OF GALVANIZED OR STAINLESS STEEL. 2x3'S TO BE NOTCHED AT EXPANSION ANCHORS AS REQ'D FOR INSTALLATION.

TO PARAPET EL. 725'-3"

PLAN OF EL. 725'-0" ON FIGURE 3-1-93



- NOTES**
1. FOR NOTES SEE DWG. C-903.
  2. STRUCTURAL CONCRETE SHALL BE CLASS 3500 (PS) @ 20 DAYS AS PER SPEC. 5525.1.
  3. FOR ADDITIONAL PENETRATION OPENINGS SEE PLANT LAYOUT REVELATION DWGS. (K-500-10) WHERE CONFLICTS EXIST THE PENETRATION DWGS. SHALL GOVERN.
  4. FIELD OPTION TO SUPPORT CRANES ON CONC. CORBELS AS SHOWN ON INTERIOR WALL ELEVATIONS AT COL. LINES 153 & 154 OR ON STEEL GIROPS SHOWN ON SECT. C, D & E.

REFERENCE DWG.	REFERENCE DWG.
BECHTEL N.Y. 11	BECHTEL N.Y. 11
C-910	C-903
C-915	E-105602
C-918	E-105595
A-205	E-105053-5
C-912	E-105586
C-911	E-105588
C-906	C-904
C-907	E-105589

TERA APERTURE CARD

NO.	DESCRIPTION	DATE	BY	CHKD.
1	REV. FOR C-334 (REV. REQ'D) AND EMC 4761 (DCA #3)	10/1/54	J.M.	J.M.
2	REV. FOR C-334 (REV. REQ'D) AND EMC 4761 (DCA #3)	10/1/54	J.M.	J.M.
3	REV. FOR C-334 (REV. REQ'D) AND EMC 4761 (DCA #3)	10/1/54	J.M.	J.M.
4	REV. FOR C-334 (REV. REQ'D) AND EMC 4761 (DCA #3)	10/1/54	J.M.	J.M.
5	REV. FOR C-334 (REV. REQ'D) AND EMC 4761 (DCA #3)	10/1/54	J.M.	J.M.
6	REV. FOR C-334 (REV. REQ'D) AND EMC 4761 (DCA #3)	10/1/54	J.M.	J.M.
7	REV. FOR C-334 (REV. REQ'D) AND EMC 4761 (DCA #3)	10/1/54	J.M.	J.M.
8	REV. FOR C-334 (REV. REQ'D) AND EMC 4761 (DCA #3)	10/1/54	J.M.	J.M.
9	REV. FOR C-334 (REV. REQ'D) AND EMC 4761 (DCA #3)	10/1/54	J.M.	J.M.
10	REV. FOR C-334 (REV. REQ'D) AND EMC 4761 (DCA #3)	10/1/54	J.M.	J.M.

**PENNSYLVANIA POWER & LIGHT COMPANY**

ALLENTOWN, PENNSYLVANIA  
 310 JOHANNAS STATION ELECTRIC STATION - UNIT 1, UNITS 2

BECHTEL - SAN FRANCISCO

**DIESEL GENERATOR BUILDING  
 WALL ELEVATIONS  
 EXTERIOR WEST WALL & INTERIOR WALLS**

JOB NO. 8856 DRAWING NO. C-909 REV. 10

Q E-105686

RSDS - PDR

802180631

