MPL NO 1H13-2645J | J-1464F

NOTES:
1. THIS DRAWING SUPERSEDES DRAWING J-1407, SH 2G

ESF DIV 2 DC BKR 72-11801 TRIP	ESF DIV 2 DC BKR 72-11803 TRIP	4160V DIV 2 BUS 16A8 UNDERVOLTAGE TRIP	4160V DIV 2 BUS 16A8 INCOMING BREAKERS TRIP
DIESEL GENERATOR B ENGINE TRIP	4160V DIV 2 DIESEL GENERATOR BREAKER TRIP		4160 DIV 2 BREAKER 152-1810 TRIP
△6	△6	480V DIV 2 BUS INCOMING BREAKER FAULT TRIP	480V DIV 2 MCC INCOMING BREAKER FAULT TRIP
DIESEL GEN B NOT AVAILABLE FOR AUTO START △5	DIESEL GENERATOR B ENGINE TROUBLE	480V DIV 2 BUS 16B3 UNDERVOLTAGE	480V DIV 2 BUS 16B32 UNDERVOLTAGE
MASTER SELECTOR SWITCH IN EMERGENCY	LOCAL ANNUN POWER SUPPLY FAILURE △5	480V DIV 2 BUS 16B83 UNDERVOLTAGE	480V DIV 2 BUS 16B84 UNDERVOLTAGE
DIV 2 LSS PANEL BREAKER CLOSING PRIORITY CHANGED	STBY DIESEL GEN DIVISION 2 TRIP UNIT TROUBLE	480V DIV 2 BUS 16B85 UNDERVOLTAGE	480V DIV 2 BUS 16B36 UNDERVOLTAGE
DIVISION 2 LSS PANEL IN TEST MODE	480V DIV 2 FEEDER BREAKER LOSS OF DC VOLTAGE	480V DIV 2 LOAD CENTER LOSS OF DC VOLTAGE	4160V DIV 2 BUS 16A8 LOSS OF DC VOLTAGE
DIV 2 HVH 2 [illegible]			ESF DIV 2 BATTERY VOLTAGE

TERA APERTURE CARD

NO	DATE	REVISION	BY	CHK	ENGR	PROJ ENGR
△	07/24/80	ISSUED FOR CONSTRUCTION SEE NOTE 1	JA	SM	LL	GT
SCALE: 6"=1'-0"		DATE 07/24/80	DRAWN ADC 8903724			ENGR

BECHTEL
GAITHERSBURG, MARYLAND

MISSISSIPPI POWER & LIGHT COMPANY
GRAND GULF NUCLEAR STATION
UNITS 1 & 2

PANEL ARRANGEMENT
DIESEL GENERATOR BENCHBOARD
1H13-P864-0A

QUALITY CLASS	DRAWING NO	REV
3845-	J-1464F	3

MPL NO 1H13-2645J

30X

RIDS-PDR

8103058838

DD AINT

NRCA ANPOF IBØ45
" " IBØ22
" " HAØ45



MMM 5824 — FILMSORT® Brand Aperture & Camera Cards and DUPLICARD® Brand Copy Cards — Product of 3M Company, St. Paul, Minn.