

4 6-12-81 ADDED INTLK 2 BAR CRACKED IN 805.
 5 3-5-82 REV. EQUIP N° TO OVM-52B WAS OVM-52A
 0 8-8-77 ISSUED FOR CONSTRUCTION

STATUS DISPLAY
 (AUX RELAY)

INDICATIONS
 START SPRING CHARGED STOP ALARM

INTERLOCKS
 COMPUTER
 (BARE CRACKED IN)

(G) (W) (R)
 STOP START
 PULL OUT OF STUDY

POSITION
 NORMAL AFTER START STOP PULL OUT OF STUDY

1 0-1-0-0-1-0 1 X X X
 2 0-1-0-0-1-0 2 X X X
 3 0-1-0-0-1-0 3 X X X
 4 0-1-0-0-1-0 4 X X X
 5 0-1-0-0-1-0 5 X X X
 6 0-1-0-0-1-0 6 X X X
 7 0-1-0-0-1-0 7 X X X
 8 0-1-0-0-1-0 8 X X X

* DENOTES SPARE
 CONTROL SW: CS
 GE TYPE SIM PULL TO LOCK
 SPRING RETURN TO NORMAL
 LOCATION: IC24

(G) (W) (R)
 STOP START
 PULL OUT OF STUDY

POSITION
 NORMAL AFTER START STOP PULL OUT OF STUDY

1 0-1-0-0-1-0 1 X X X
 2 0-1-0-0-1-0 2 X X X

CONTROL SW: CS-5
 GE TYPE SB-1
 SPRING RETURN TO NORMAL
 LOCATION: IC114

(G) (W) (R)
 STOP START
 PULL OUT OF STUDY

POSITION
 NORMAL AFTER START STOP PULL OUT OF STUDY

1 0-1-0-0-1-0 1 X X X
 2 0-1-0-0-1-0 2 X X X

CONTROL SW: CS-L
 GE TYPE SB-1
 SPRING RETURN TO NORMAL
 LOCATION: 1A06

VALVE IM0-1907
 (E-1944) SH 2

STATUS DISPLAY
 (E-205 SH 7)

UNIT COOLER
 (E-205 SH 7)

INTLK
 1SV16000B
 E-212 SH 4

INTLK
 1SV16000B
 E-212 SH 4

SPARES

SEPARATION BARRIER

SPARE COMPONENT COOLING WATER PUMP OP-73

SCHEME 1BA0608
 SU DESIG. O EGA

PRC
 APERTURE
 CARD

BECHTEL
 ANN ARBOR, MICHIGAN

MIDLAND PLANT UNITS 1 & 2
 CONSUMERS POWER COMPANY

SCHEMATIC DIAGRAM
 SPARE COMPONENT COOLING WTR PUMP

7220
 E-206Q SH 4
 5

"I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document submitted to the contractor for filing, by Bechtel Power Corporation.

3-12-82 M. CSICSAI J. [Signature]
DATE CAMERA OPERATOR CONTRACTOR'S SUP'VR
OR MANAGER

16X

RDS

8205130612

