


**NOTES**  
 1. ALL FLOORS AND CEILINGS SHALL BE 3 HOUR RATED BARRIERS. PENETRATIONS SHALL BE SEALED TO MAINTAIN FIRE RESISTANCE RATING FOR ALL BARRIERS.

**PLANT ORIENTATION**




**LEGEND OF SYMBOLS**

- THREE HOUR FIRE RATED BARRIER (INCLUDE SAFETY & PROPERTY PROTECTION)
- TWO HOUR FIRE RATED BARRIER (INCLUDE SAFETY & PROPERTY PROTECTION)
- ONE HOUR FIRE RATED BARRIER (INCLUDE SAFETY)
- ONE HOUR FIRE RATED BARRIER (INCLUDE SAFETY)

FILE NAME: K20003.DWG    INSERT NAME: PLANS1.DWG

**SYSTEM 90+™  
 DESIGN CERTIFICATION**

DRAWING TITLE  
 NUCLEAR ISLAND  
 FIRE BARRIER LOCATION  
 PLAN AT EL. 91+9



**SI  
 APERTURE  
 CARD**

9202120265

PDR

