

MODE A NORMAL OPERATING

POSITION		1	2	3A 3B	4A 4B	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
FLOW m^3/H	RCW (A), (B)	1120	1120	1120	1120	1120	604	—	—	525	245	280	40	160	295	100	—	—	245	280	525	40	160	295	100	604
	RCW (C)	726	726	726	726	726	675	—	—	51	51		40			635	—	—	51		51	40			635	675
PRESSURE Kg/cm^2 G	RCW (A), (B)	3.3	9.1	9.1	8.4			—	—					8.3			—	—					8.2			
	RCW (C)	3.9	9.2	9.2	8.5			—	—								—	—								
TEMPERATURE (°C)	RCW (A), (B)	43.4	43.4	43.4	35.0	35.0	35.0	—	—	35.0	35.0	35.0	35.0	35.0	35.0	35.0	—	—	36.0	40.9	40.0	40.3	65.1	36.0	38.4	49.3
	RCW (C)	47.9	47.9	47.9	35.0	35.0	35.0	—	—	35.0	35.0		35.0			35.0	—	—	35.0		35.0	39.7			49.4	49.8

MODE B REACTOR SHUTDOWN (AT 4 HOURS)

POSITION		1	2	3A 3B	4A 4B	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
FLOW m^3/H	RCW (A), (B)	2320	2320	1163	1163	2320	604	1200	—	525	245	280	40	160	295	100	1200	—	245	280	525	40	160	295	100	604
	RCW (C)	1026	1026	963	963	1026	675	1200	—	51	51		40			635	1200	—	51		51	40			635	675
PRESSURE Kg/cm^2 G	RCW (A), (B)	3.3	9.1	9.1	8.4			8.6	—					8.3			7.9	—					8.2			
	RCW (C)	3.9	9.2	9.2	8.5			8.1	—								7.4	—								
TEMPERATURE (°C)	RCW (A), (B)	48.1	48.1	48.1	35.0	35.0	35.0	35.0	—	35.0	35.0	35.0	35.0	35.0	35.0	35.0	36.5	—	39.5	40.9	40.2	40.3	39.0	39.9	38.4	38.4
	RCW (C)	53.3	53.3	53.3	35.0	35.0	35.0	35.0	—	35.0	35.0		35.0			35.0	36.5	—	37.3		37.3	39.7			49.4	49.8

MODE C REACTOR SHUTDOWN (AT 20 HOURS)

POSITION		1	2	3A 3B	4A 4B	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
FLOW m^3/H	RCW (A), (B)	2320	2320	1163	1163	2320	604	1200	—	525	245	280	40	160	295	100	1200	—	245	280	525	40	160	295	100	604
	RCW (C)	1026	1026	963	963	1026	675	1200	—	51	51		40			635	1200	—	51		51	40			635	675
PRESSURE Kg/cm^2 G	RCW (A), (B)	3.3	9.1	9.1	8.4			8.6	—					8.3			7.9	—					8.2			
	RCW (C)	3.9	9.2	9.2	8.5			8.1	—								7.4	—								
TEMPERATURE (°C)	RCW (A), (B)	34.1	34.1	34.1	28.5	28.5	28.5	28.5	—	28.5	28.5	28.5	28.5	28.5	28.5	28.5	35.4	—	33.0	34.4	33.7	33.8	28.5	33.4	31.8	31.8
	RCW (C)	37.7	37.7	37.7	28.5	28.5	28.5	28.5	—	28.5	28.5		28.5			28.5	36.4	—	30.0		30.0	33.2			42.9	42.3

MODE D HOT STAND-BY

POSITION		1	2	3A 3B	4A 4B	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
FLOW m^3/H	RCW (A), (B)	1120	1120	1120	1120	1120	604	—	—	525	245	280	40	160	295	100	—	—	245	280	525	40	160	295	100	604
	RCW (C)	726	726	726	726	726	675	—	—	51	51		40			635	—	—	51		51	40			635	675
PRESSURE Kg/cm^2 G	RCW (A), (B)	3.3	9.1	9.1	8.4			—	—					8.3			—	—					8.2			
	RCW (C)	3.9	9.2	9.2	8.5			—	—								—	—								
TEMPERATURE (°C)	RCW (A), (B)	43.4	43.4	43.4	35.0	35.0	35.0	—	—	35.0	35.0	35.0	35.0	35.0	35.0	35.0	—	—	38.1	40.9	40.1	40.3	65.1	38.0	38.4	49.3
	RCW (C)	47.9	47.9	47.9	35.0	35.0	35.0	—	—	35.0	35.0		35.0		35.0	35.0	—	—	35.0		35.0	39.7			49.4	49.8

MODE E HOT STAND-BY LOSS OF ACP

POSITION		1	2	3A 3B	4A 4B	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
FLOW m^3/H	RCW (A), (B)	2459	2459	1230	1230	2459	504	1200	230	525	245	280	40	160	295	—	1200	230	245	280	525	40	160	295	—	504
	RCW (C)	1521	1521	761	761	1521	40	1200	230	51	51		40		60	—	1200	230	51		51	40			—	40
PRESSURE Kg/cm^2 G	RCW (A), (B)	3.3	9.1	9.1	8.4			8.6						8.3		—	7.9						8.2		—	
	RCW (C)	3.9	9.2	9.2	8.5			8.1								—	7.4								—	
TEMPERATURE (°C)	RCW (A), (B)	42.1	42.1	42.1	35.0	35.0	35.0	35.0	35.0	35.0	35.0	35.0	35.0	35.0	35.0	—	39.8	48.7	39.8	40.9	40.4	38.8	65.1	37.7	—	48.5
	RCW (C)	41.0	41.0	41.0	35.0	35.0	35.0	35.0	35.0	35.0	35.0		35.0			—	38.8	48.7	37.3		37.3	37.8			—	37.9

MODE F SUPPRESSION POOL COOLING (LOCA S/P 97 °C)

POSITION		1	2	3A 3B	4A 4B	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
FLOW m^3/H	RCW (A), (B)	2004	2004	1002	1002	2004	49	1200	230	525	245	280	49	—	—	—	1200	230	245	280	525	49	—	—	—	49
	RCW (C)	1521	1521	761	761	1521	40	1200	230	51	51		40			—	1200	230	51		51	40			—	40
PRESSURE Kg/cm^2 G	RCW (A), (B)	3.3	9.1	9.1	8.4			8.6						—	—	—	7.9						—	—	—	
	RCW (C)	3.9	9.2	9.2	8.5			8.1								—	7.4								—	
TEMPERATURE (°C)	RCW (A), (B)	48.2	48.2	48.2	35.0	35.0	35.0	35.0	35.0	35.0	35.0	35.0	35.0	—	—	—	53.0	48.7	39.8	43.1	41.6	38.5	—	—	—	38.5
	RCW (C)	51.6	51.6	51.6	35.0	35.0	35.0	35.0	35.0	35.0	35.0		35.0			—	53.0	48.7	40.4		40.4	39.3			—	39.3

MODE G SUPPRESSION POOL COOLING (LOCA S/P 57 °C)

POSITION		1	2	3A 3B	4A 4B	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
FLOW m^3/H	RCW (A), (B)	2004	2004	1002	1002	2004	49	1200	230	525	245	280	49	—	—	—	1200	230	245	280	525	49	—	—	—	49
	RCW (C)	1521	1521	761	761	1521	40	1200	230	51	51		40			—	1200	230	51		51	40			—	40
PRESSURE Kg/cm^2 G	RCW (A), (B)	3.3	9.1	9.1	8.4			8.6						—	—	—	7.9						—	—	—	
	RCW (C)	3.9	9.2	9.2	8.5			8.1								—	7.4								—	
TEMPERATURE (°C)	RCW (A), (B)	39.7	39.7	39.7	32.6	32.6	32.6	32.6	32.6	32.6	32.6	32.6	32.6	—	—	—	35.7	48.3	37.3	40.7	39.2	38.1	—	—	—	38.1
	RCW (C)	39.8	39.8	39.8	32.6	32.6	32.6	32.6	32.6	32.6	32.6		32.6			—	38.7	48.3	38.0		38.0	36.9			—	35.9

TABLE 1 RCW VALVE POSITION CHART

	F008	F010	F012	F055	F072	F074	F075	F080	F081	F082	F101	F141
MODE A	O-T	C-T	C	C	O	O	O	O	O	O	O	O
MODE B	O-T	C-T	O-T	C	O	O	O	O	O	O	O	O
MODE C	O-T	C-T	O	C	O	O	O	O	O	O	O	O
MODE D	O-T	C-T	C	C	O	O	O	O	O	O	O	O
MODE E	O-T	C-T	O-T	O	O	O	O	O	O	O	O	C
MODE F	O	C	O	O	O	O	C	C	C	O	C	C
MODE G	O	C	O	O	O	O	C	C	C	O	C	C

O = VALVE OPEN
T = VALVE THROTTLED
C-T = VALVE CLOSED OR THROTTLED
O-T = VALVE OPEN OR THROTTLED
C = VALVE CLOSED

NOTES:

1. [X] — INDICATES THE DATA IS NOT SIGNIFICANT.
   [ ] — INDICATES THE DATA FLOW EQUALS ZERO.
   [/] — INDICATES THE DATA IS NOT IN THE SYSTEM.
2. ALLOWABLE AM BOND LOWER VALUES FOR EQUIPMENT SHALL BE 1mg AND LONG.
3. TABLE 1 INDICATES VALVE POSITIONS DURING EACH OPERATING MODE.
4. THE VALUES OF RCW (A) AND RCW (B) ARE TYPICAL TO THE VALUES OF RCW (A).
5. RCWS SYSTEM DESIGN PRESSURE AND TEMPERATURE ARE AS FOLLOWS:

SYSTEM	DESIGN PRESSURE	DESIGN TEMPERATURE
	Kg/cm^2 G	(°C)
RCW	14.0	70

6. RCW PUMP FLOW AND HEAD ARE AS FOLLOWS:

SYSTEM	PUMP FLOW m^3/H	PUMP HEAD (mAq)
RCW (A), (B)	1200	35
RCW (C)	1200	35

REFERENCE DOCUMENTS:

1. REAC BLDG COOLING WATER SYS P&ID — MPL NO. P21-1010

F16. 9.2-1aa

MPL NO. P21-1020

SI APERTURE CARD

SIGNATURES			
DRAWN	W. TORRES	6-24-77	
CHECKED	VALDEZ	6-24-77	
ENG.	G.A. EATON	6-24-77	
MGR.	C.E. MILLER	6-24-77	

APPLIED PRACTICES: UNLESS OTHERWISE SPECIFIED — TOLERANCES ON: 2 PLACE DECIMALS ±, 3 PLACE DECIMALS ±, FRACTIONS ±, ANGLES ±

SAFETY RELATED — THIS ITEM IS OR CONTAINS A SAFETY RELATED ITEM: ☐ YES ☒ NO

ITEM CLASS TO HAZARDS SAFETY RELATED: ☐ YES ☒ NO

Nuclear Energy — GENERAL ELECTRIC COMPANY San Jose CA

DOC. TYPE: PFD

REACTOR BUILDING COOLING WATER SYSTEM

PRE COST CODE: 6-24-77

107E6004 — REV. 0

SCALE: NONE — SHEET 1 OF 1

AP-5978020

PDR RIDS

9202250349



MMM 5824 FILMSORT® & DUPLICARD® Cards 3M St. Paul, MN