



UNCONTROLLED DRAWING
 Copy Date: 5/11/92
 Caution-Extended use of this drawing copy may result in its inaccuracy due to subsequent design changes and drawing updates.

- NOTES:**
1. ALL EQUIPMENT & INSTRUMENT NUMBERS NOT PREFIXED ON DRAWING ARE PREFIXED WITH 19 WHICH IS SYSTEM 19.
 2. ALL SWITCHES DRIVE A COMMON ALARM LOCATED IN NUC. CONTROL ROOM & A LOCAL INDICATING LIGHT. (19A-61, 09-3, 1-9)
 3. *G.E.* FURNISHED WITH EQUIPMENT.

- REFERENCE:**
1. FLOW DIAGRAM SYMBOLS FM-14A
 2. FLOW DIAGRAM - FUEL POOL FILTER DEMINERALIZER SYSTEM NO. 19-4 FM-19B

- 1ST COMPONENT
 CLASS 1
 CLASS 2
 CLASS 3

THE ORIGINAL TRACING FOR THIS DRAWING WAS PREPARED BY: STONE & WEBSTER CORP.
 A RECORD OF THE ORIGINAL DOCUMENT WITH APPROVAL INITIALS, SIGNATURES AND THE P.E., SEAL, AND EXPIRATION DATE OF THE REGISTERED PROFESSIONAL ENGINEER, IS MAINTAINED IN THE FILES OF THE POWER AUTHORITY & DESIGNATING ENGINEER SECTION 4-2-6.
 THIS DOCUMENT WAS ELECTRONICALLY STORED AT REVISION 16.

SI APERTURE CARD

QA CAT. I, II, III
 NUCLEAR SAFETY RELATED
JAMES A. FITZPATRICK
 NUCLEAR POWER PLANT
FLOW DIAGRAM
FUEL POOL COOLING
& CLEAN-UP SYSTEM NO. 19

REV	DATE	DESCRIPTION	BY	CHKD	APP'D
22	11/88	AS-BUILT PER DCR-90-242
21	11/88	AS-BUILT PER DCR-89-035
20	11/88	AS-BUILT PER DCR-89-012

REV	DATE	DESCRIPTION	BY	CHKD	APP'D
19	11/88	AS-BUILT PER MOD. NO. N1-88-165
18	11/88	AS-BUILT PER DCR-89B-004
17	11/88	AS-BUILT PER DCR-87-011

New York Power Authority
 SCALE NONE
 DWG NO 11825-FM-19A
 SHEET 22

9206150370

PDR RIDS

9206150370

