

From: Wentworth, Theodore R. (EGLE) <WentworthT@michigan.gov>
Sent: Friday, August 14, 2020 11:47 AM
To: Arora, Surinder
Cc: Asselin, David (EGLE); Skutt, David (EGLE)
Subject: [External_Sender] RE: ACTION - Request for Comments on the Proposed Issuance of Amendments to Technical Specifications for Fermi 2 Nuclear Power Plant (EPID L-2019-LLA-0200)

Mr. Arora,
Thank you for the opportunity to review and comment on the proposed license amendment for the Fermi 2 nuclear power plant, ADAMS accession No. ML19248C571.

My staff have reviewed the amendment request and relevant NRC subject correspondence. We have no additional comments or questions on the proposed amendment.

Thank you

T.R. Wentworth II, Manager
Radiological Protection Section
Materials Management Division
Michigan Department of Environment, Great Lakes, and Energy
Phone : 517-915-8881
wentwortht@michigan.gov

From: Arora, Surinder <Surinder.Arora@nrc.gov>
Sent: Wednesday, August 12, 2020 13:03
To: Wentworth, Theodore R. (EGLE) <WentworthT@michigan.gov>
Subject: ACTION - Request for Comments on the Proposed Issuance of Amendments to Technical Specifications for Fermi 2 Nuclear Power Plant (EPID L-2019-LLA-0200)

CAUTION: This is an External email. Please send suspicious emails to abuse@michigan.gov

Dear Mr. Wentworth,

I had sent the following message to Mr. Asselin, who advised me that You would be responding to request like this.

The U.S. Nuclear Regulatory Commission (NRC) plans to issue amendment to Fermi 2 Nuclear Power Plant (Fermi 2) technical specifications (TS) in response to DTE Energy Company's (DTE) proposed amendment request.

The proposed amendment would revise the Fermi 2 TS 2.1.1, "Reactor Core SLs" reactor steam dome pressure from 785 psig to 686 psig and TS Table 3.3.6.1-1, "Primary Containment

Isolation Instrumentation,” Function 1.b, “Main Steam Line Pressure – Low” isolation function allowable value from 736 psig to 801 psig.

DTE’s amendment request, dated September 5, 2019, is publicly available in the NRC’s Agencywide Documents Access and Management System (ADAMS) at Accession No. ML19248C571. It appears that a copy of the amendment request was also cc’d by DTE to Michigan Public Service Commission, Regulated Energy Division (email: kindsch1@michigan.gov). The NRC has issued a proposed finding that the amendment involves no significant hazards consideration on December 3, 2019 (84 FR 66227).

Please let me know if the Michigan State has any comments on this proposed amendment by August 21, 2020.

Thank you for your time.

Regards,

SURINDER ARORA, PE

Project Manager, Fermi 2
US NUCLEAR REGULATORY COMMISSION
OFFICE OF NUCLEAR REACTOR REGULATION (NRR)
DIVISION OF OPERATING REACTOR LICENSING (DORL)
Plant Licensing Branch III (LPL3)

Phone: 301 415-1421

Email: Surinder.Arora@nrc.gov

Hearing Identifier: NRR_DRMA
Email Number: 789

Mail Envelope Properties (DM6PR09MB54933EA57B9FDB61731E7742AE400)

Subject: [External_Sender] RE: ACTION - Request for Comments on the Proposed Issuance of Amendments to Technical Specifications for Fermi 2 Nuclear Power Plant (EPID L-2019-LLA-0200)

Sent Date: 8/14/2020 11:47:24 AM
Received Date: 8/14/2020 11:47:32 AM
From: Wentworth, Theodore R. (EGLE)

Created By: WentworthT@michigan.gov

Recipients:

"Asselin, David (EGLE)" <AsselinD1@michigan.gov>
Tracking Status: None
"Skutt, David (EGLE)" <SkuttD@michigan.gov>
Tracking Status: None
"Arora, Surinder" <Surinder.Arora@nrc.gov>
Tracking Status: None

Post Office: DM6PR09MB5493.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	2790	8/14/2020 11:47:32 AM

Options

Priority: Normal
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date: