


**SI APERTURE CARD**

- NOTES
1. ORIFICE PLATE IN THE PUMP DISCHARGE FLANGE WITH A 3/8 INCH DIA. HOLE DRILLED IN ITS CENTER
  2. L.M. LOCKED HANDWHEEL
  3. DRAIN LINE ADDED TO CHECK VALVE COVER TO ASSURE SUFFICIENT DRAINAGE TO UNCOVER VALVE DISC
  4. 4" 300# FLANGE, SERVICE AIR TEST CONNECTION TO CHECK NOZZLE FLOW ADDED TO FLANGE PER MR 87-02E
  5. 3/4" DIA. HOLE FOR CONTINUOUS DRAIN

NOTE  
THIS DRAWING REDRAWN FROM WESTINGHOUSE ELECTRIC COOP. DRAWING #110E035 SH. 3 REV. 30



PROJECT NO.	18976		ISI CLASSIFICATION DIAGRAM SAFETY INJECTION SYSTEM POINT BEACH NUCLEAR PLANT UNIT 2 110E035 CBD SH. 3
DATE	11/21/68		
DESIGNED BY	W. J. B. / W. J. B.		E. P. B. 02MSIK000002
CHECKED BY	W. J. B. / W. J. B.		
APPROVED BY	W. J. B. / W. J. B.	18" LEVELS USED: 29, 30, 31, 32, 33, 34, 35, 36, 39	

FOR INFORMATION ONLY



PDR RIDS

9302030312

