

SRUPPS JOB NO. 10468 RFP: SPECIFICATION 10468-J-209 BILL OF MATERIAL MAIN CONTROL PANEL PANEL NO. RLO06 REV. NO. 22									
ITEM NO.	INSTRUMENT NO.	UNIT NO.	SERVICE	DESCRIPTION	ELEMENTARY DWG.	SUPPLIER	SEP. GROUP	REMARKS	REV.
24	MB-HS-3	ALL	DC VOLTAGE REGULATOR	GE SBW	EO3MB10	GE	NV	44A336T04-001	9
25A	MB-II-1		GEN FIELD AMPUTER	SIGMA 1151VB	EO3MB01	CBV		DC AMPS 0-8000 AMPS 1151VB4-20 DCMA	
25B	MB-EI-4		GEN FIELD VOLTMEYER					DC VOLTS 0-600V 1151VB-20 DCMA	
26A	MB-HS-4		PWR STABILIZER REMOTE CTRL	GE SBW	EO3MB12	GE			
26B	MB-ZL-4		PWR STABILIZER IND LIGHTS	GE ET-18				0116B6708 5G 5R	
27	MB-JI-4		PWR STABILIZER METER	SIGMA 1151V		CBV		LEGEND: DC VOLTS -10V ~ 0 ~ +10V 1151VC20 DCV	
28	AE FS/510C		FR-510 FEED FLOW SEL SW	ELECTROSWITCH MODEL 20KD	E-035C01,09 M-761-140 C5			CAT# 20KD-0904D4-002	9
29	AB ZL-1A		SG A STM DUMP TO ATMOS VLV POSN	GE ET-18	E-03AB06			0116B6708 3R 3G	
30	AB PIC-1A		SG A STM DUMP TO ATMOS CTRL	FOXBORO 25OHM+M2NH	E-03AB20	BECHTEL			
31	AB FS/512C		FR-510 STM FLOW SEL SW	ELECTROSWITCH MODEL 20KD	E-035C01,09 M-761-140 C5	CBV	NV	CAT# 20KD-0904D4-002	9
32	AB HL-1		SG A STM DUMP CTRL AT SHUTDN PNL	GE ET-18	E-03AB20			0116B6708 3W	
33	AE FS/520C		FR-520 FEED FLOW SEL SW	ELECTROSWITCH MODEL 20KD	E-035C01,09 M-761-142 C6		NV	CAT# 20KD-0904D4-002	9
34	AB ZL-2A		SG B STM DUMP TO ATMOS VLV POSN	GE ET-18	E-03AB06		2	0116B6708 3R 3G	
35	AB PIC-2A		SG B STM DUMP TO ATMOS CTRL	FOXBORO 25OHM+M2NH	E-03AB20	BECHTEL	2		
36	AB FS/522C		FR-520 STM FLOW SEL SW	ELECTROSWITCH MODEL 20KD	E-035C01,09 M-761-142 C6	CBV	NV	CAT# 20KD-0904D4-002	9
37	AB HL-2		SG B STM DUMP CTRL AT SHUTDN PNL	GE ET-18	E-03AB20		2	0116B6708 3W	
38	AE FS/530C		FR-530 FEED FLOW SEL SW	ELECTROSWITCH MODEL 20KD	E-035C02,09 M-761-144 C7		NV	CAT# 20KD-0904D4-002	9
39	AB ZL-3A		SG C STM DUMP TO ATMOS VLV POSN	GE ET-18	E-03AB06		3	0116B6708 3R 3G	
40	AB PIC-3A		SG C STM DUMP TO ATMOS CTRL	FOXBORO 250 HMM+M2NH	E-03AB20	BECHTEL	3		
41	AB FS/532C		FR-530 STM FLOW SEL SW	ELECTROSWITCH MODEL 20KD	E-035C02,09 M-761-144 C7	CBV	NV	CAT# 20KD-0904E4-002	9
42	AB HL-3		SG C STM DUMP CTRL AT SHUTDN PNL	GE ET-18	E-03AB20		3	0116B6708 3W	
43	AE FS/540C		FR-540 FEED FLOW SEL SW	ELECTROSWITCH MODEL 20KD	E-035C02,09 M-761-146 C8		NV	CAT# 20KD-0904D4-002	
44	AB ZL-4A		SG D STM DUMP TO ATMOS VLV POSN	GE ET-18	E-03AB06		4	0116B6708 3R 3G	

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document(s) submitted for Micrographics.
DATE 2-28-82 OPERATOR *Denny Denny* SUPERVISOR *Al H. H. H.*

16X

TERA
APERTURE
CARD

RIDS-PDR

8104070114

