




NOTES:-

1. FOR LEGEND, NOTES, REFERENCES, AND STANDARD DETAILS, SEE DWG. 0-215-001.
2. CONDUITS CONTINUED DOWN, SEE DWG. 0-215-131.
CONDUITS CONTINUED UP, SEE DWG. 0-215-151.
3. WHEN ADDING A SEISMIC THREADED ROD SUPPORT (TYPE 1) TO DECKING MAKE SURE ANCHOR BOLT IS FASTENED TO HIGH PART OF DECKING.
4. THIS DRAWING TO BE WORKED IN CONJUNCTION WITH THE FOLLOWING ELECTRICAL SUPPORT DRAWINGS AS LISTED IN TABLE "A".



NUCLEAR SAFETY RELATED

EAR SAFETY RELATED		NO		DATE		NAME	CHECK	APPROVAL
REVISED								
487	CONSTRUCTION SP 25							11
LIMITED CONSTRUCTION HAS NOTED PRELIMINARY NOT FOR CONSTRUCTION BIDDING PURPOSES								
DATE		RELEASED FOR					ENGR.	
THE CLEVELAND ELECTRIC ILLUMINATING COMPANY								
PERRY NUCLEAR POWER PLANT						UNITS 1 & 2		
ELECTRICAL CONDUNIT LAYOUT								
CONTROL COMPLEX - EAST - LN. 538'-6"								
READING		GILBERT ASSOCIATES, INC.					GID	
PA		ENGINEERS AND CONSULTANTS						
DRAWING		ENGINEER APPROPRIATE						
BY		T. W. TORCHET		J. C. TORCHET		ELECTRICAL		
CHECKED		T. W. TORCHET		J. C. TORCHET		ELECTRICAL		
DATE		10-1-68		10-1-68		10-1-68		
SCALE		1" = 1'-0"		1" = 1'-0"		1" = 1'-0"		
04		4549		D-215-141		F		
04148-18		DRAWING NUMBER					REV.	

810 4080592

