



**INFORMATION ONLY.**

- NOTES:
- FOR GENERAL NOTES & REFERENCE DWGS SEE DWG NO. 5613-M-3019 SH. 1.
  - DELETED
  - ALL PIPING IS QUALITY GROUP  UNLESS OTHERWISE NOTED.
  - PIPING FROM THE CHEMICAL INJECTION NOZZLE ISOLATION VALVE TO THE CHEMICAL INJECTOR POINT SHALL BE HASTELLOY C276 INSTALLED IN ACCORDANCE WITH SPECIFICATION 517-PS-21.
  - LINE SIZE TRANSITIONS AT MAJOR TEES ARE PROVIDED BY REDUCING TEES IN SIZES INDICATED BY PIPE LINE SPECIFICATIONS.

REV	DATE	REVISION	BY	CHK	APP	REV	DATE	REVISION	BY	CHK	APP
9	9/29/93	ISSUED AS-BUILT FOR PC/M 92-115.	SMI	MD	LK	MEM	12-23-92	ISSUED AS-BUILT FOR PC/M 89-542 AND DCR-TPM-92-215.	SMI	MD	LK
8	09-20-93	ISSUED AS-BUILT FOR PC/M 93-084.	SMI	MD	LK	MEM	11-5-92	ISSUED AS-BUILT FOR DCR-TPM-92-0311.	SMI	MD	LK
7	04-01-93	ISSUED AS-BUILT FOR PC/M 93-046.	HKS	AB	LK	MEM	9-3-92	ISSUED AS-BUILT FOR DCR-TPM-92-180.	SMI	MD	LK
6	03-06-93	ISSUED AS-BUILT FOR DCR-TPM-93-075.	LSH	INITIALS ON FILE			6-1-92	ISSUED AS-BUILT FOR PC/M 89-452.	SMI	MD	LK
5	2-7-93	ISSUED AS-BUILT FOR PC/M 92-080.	SP	INITIALS ON FILE			1/29/91	THIS DWG CREATED PER THE P & ID RECONSTRUCTION PROJECT SCOPE AND ISSUED INTO THE FPL DWG SYSTEM PER DCR-TPM-90-541.	SMI	MD	LK

ANSTEC APERTURE CARD

NOTE: THIS DWG IS MADE FROM:  
FPL P00 5610-I-E-4065, SH. 2 REV. 63.

TURKEY POINT NUCLEAR UNIT 3		STONE & WEBSTER ENGINEERING CORP. FT. LAUDERDALE, FLORIDA	
P I D		DRAWING NUMBER	
INTAKE COOLING WATER SYSTEM		5613-M-3019	
SHEET 2		SYS	
		REV	
		9	
		UTM00073.DWG	

POD



9406210175

PDR RIDS

