



REFERENCES:
COMPLETE LIST OF ELECTRICAL DRGS. 237127A-E200

- NOTES:
1. ALL CABLES, TOP ENTRY.
 2. LOCK WASHERS TO BE USED ON ALL TERMINAL CONNECTIONS.
 3. 480V. GROUND DETECTOR CABINETS BY RELIANCE ELECTRIC CO., ORDER K-422.
 4. ELECTRICAL CONTRACTOR (K-262) TO SUPPLY AND INSTALL ALL FUSES AS SHOWN.

PRO
APERTURE
DATA

237127A-E564

NO.	DESCRIPTION	DATE

RC

WISCONSIN PUBLIC SERVICE CORPORATION
Kewaunee Nuclear Power Plant - Unit No. 2
CARLTON Kewaunee County, Wisconsin

**W/D GROUND DETECTOR CABINETS
RD17 & RD18**

Prepared by Pioneer Service & Engineering Co.

DATE	
BY	
CHECKED	
NOTED	
REVISIONS	

237127A-E564

8309120515

RIDS

8309120525

