



- NOTES**
1. ALL TUBING IS 3/4" SL-2509 UNLESS OTHERWISE NOTED.
 2. FOR EQUIPMENT LOCATION SEE STORE & WEISBERG DRAWINGS 13007-54-EP-1A & 13007-54-EP-1B.
 3. FOR GAS ANALYZER (SL-24) SEE STORE & WEISBERG DRAWING 13007-54-EP-1C.
 4. REVISIONS 2 THRU 8 WERE MADE BY OPPO IN THEIR OFFICE.

PRC APERTURE CARD

8212060256

NON-CQE

NO	DESCRIPTION	CHKD	CORRECT	DATE	REV.	DESCRIPTION	DRWN	CHKD	ENGR	DATE
10	DRAWING REDRAWN TO OPPO REQUESTED FORMAT	---	---	---	---	---	---	---	---	---
9	DRAWING VOIDED RENUMBERED 13007-54-EN-14-D-3	---	---	---	---	---	---	---	---	---
8	ADDED VALVES HCV-2504, 2505, 2506	---	---	---	---	---	---	---	---	---
7	ADDED LINE L-28A, HCV-2509, SL-57, SL-516, SL-517, RELOCATED VALVE HCV-1973, ADDED TEES TO LINE L-50	---	---	---	---	---	---	---	---	---
6	ADDED VALVES SL-250, SL-728, SL-673, HCV-674S.	---	---	---	---	---	---	---	---	---
5	ADDED TEST CONN. LOCATIONS	---	---	---	---	---	---	---	---	---
4	ISSUED FOR CONSTRUCTION	---	---	---	---	---	---	---	---	---
3	GENERAL REVISION FOR BIDS ONLY	---	---	---	---	---	---	---	---	---
2	ORIGINAL ISSUE	---	---	---	---	---	---	---	---	---
1	FOR BIDS ONLY	---	---	---	---	---	---	---	---	---

POST ACCIDENT SAMPLING SYSTEM
NUREG 0737 SECT II B 3
 CHAMA PUBLIC POWER DISTRICT
 POST ACCIDENT SAMPLING SYSTEM
 WORK ORDER NO. 1967
 13007-54-EN-14

66 L
 66 11
 66 5
 8.5
 11
 17

66 8
 66 11
 66 5
 8.5
 11
 17

Rids

8212060256

