



LEGEND:

- △ INTERNAL WIRE MARK
- EXTERNAL WIRE MARK (SEE NOTES 2 AND 3)
- ◇ SWITCHGEAR TERMINAL
- AUX GE RELAY IZHGAIJ2
- DI CLASS I E DIVISION 1
- N NON-CLASS I E
- 50/51 GE IFC 66A

NOTES:

1. ALL DEVICES WITHOUT LOCATION MARKS ARE IN SWITCHGEAR.
2. ALPHABETICAL WIRE MARKS ARE PREFIXED BY SUBSYSTEM NO., SHEET AND LINE NO. (EXAMPLE: B33A2703A).
3. POTENTIAL WIRE MARKS ARE PREFIXED BY SUBSYSTEM NO. AND SHEET NO. (EXAMPLE: B33A2703P).
4. DEVICE DESIGNATIONS ARE PREFIXED BY UNIT AND SYSTEM NO. (EXAMPLE: 1B33-0001).
5. FOR GRAPHIC STANDARDS, REFER TO DWG. B-208-001.
6. FOR RELAY STANDARDS, REFER TO DWG. B-208-002.
7. FOR SWITCH DEVELOPMENTS, REFER TO SHEETS 02 AND 03.

REFERENCES:
820E466A SHEET 22, U.C. CO. DRAWING

PRC APERTURE CARD

NUCLEAR SAFETY RELATED

THE CLEVELAND ELECTRIC ILLUMINATING CO.

FERRY NUCLEAR POWER PLANT UNIT 3
ELECTRICAL-ELEMENTARY DIAGRAM

REACTOR RECIRCULATION SYSTEM
RECIRCULATION PUMP CONTROL
BREAKER CONTROL SA

CHANGED AUX RELAY LEGEND FROM CTR-1100 TO S.E. AND ADDED AUX CONTACTS PER DWG.	ADDED FITS INFORMATION REMOVED # REF DWG. WIRE MARKS, WIRE & CONTACT 'Q'	ADDED FITS INFORMATION PER PY-GENGAI-1498	5-F-78 CONSTRUCTION PRELIMINARY RELEASED FOR ENGR.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS	04 4649 B-208-011
CHANGED CTS TO 800/5	ADDED PROTECTIVE RELAYING OF IFC-66X PER C.E. 2/12/82	ADDED FITS TERM. INFO. REV PER SE DRAWING	DATE	PA.	H
REVISED FITS TERM. NOS. PER GE REVISION	ADDED FITS INFORMATION REDRAWN TO MOVE ISOLATOR TO LOCAL BOARD	REVISED FITS TERM. NOS. PER GE REVISION	04/549-000	WV RAM DEG	04 4649 B-208-011
REVISED FITS TERM. NOS. PER GE REVISION	ADDED FITS INFORMATION REDRAWN TO MOVE ISOLATOR TO LOCAL BOARD	REVISED FITS TERM. NOS. PER GE REVISION	04/549-000	WV RAM DEG	04 4649 B-208-011

ELEM DIAG OF REACTOR RECIRCULATION PUMP CONTROL BREAKER CONTROL SA

Rids

82-2140010

