



- LEGEND:-**
- ⊙ EXTERNAL WIRE MARK (SEE NOTES 2 AND 3)
 - ⊞ INTERNAL WIRE MARK
 - ◇ SWITCHGEAR TERMINAL
 - AUX GE RELAY 12HG111J2
 - Ⓛ CLASS 1E DIVISION
 - Ⓜ NON-CLASS 1E
 - 50/51 GE IFC-66K

- NOTES:-**
1. ALL DEVICES WITHOUT LOCATION MARKS ARE IN SWITCHGEAR.
 2. ALPHABETICAL WIRE MARKS ARE PREFIXED BY: SUBSYSTEM NO., SHEET AND LINE NO. (EXAMPLE: 033A203A).
 3. POTENTIAL WIPE MARKS ARE PREFIXED BY: SUBSYSTEM NO., AND LINE NO. (EXAMPLE: 033A20CW).
 4. DEVICE DESIGNATIONS ARE PREFIXED BY UNIT AND SYSTEM NO. (EXAMPLE: 1033-C001B).
 5. FOR GRAPHIC STANDARDS, REFER TO DWG. D-200-001.
 6. FOR RELAY STANDARDS, REFER TO DWG. D-200-002.
 7. FOR SWITCH DEVELOPMENTS, REFER TO SHEETS 02 AND 03.

REFERENCES:-
028E408CA SHEET 22, G.E. CO. DRAWING

APERTURE CARD

CHANGED AUX RELAY LEGEND FROM CUTLER-HAMMER TO GE AND OPEN AIDS CIRCUIT PER GE.

ADDED CT'S TO 800/5

ADDED PROTECTIVE RELAYING. GE IFC-66K PER GE REQUEST

ADDED SWGR. TERM. INFO. REVISED TERMINAL POINTS REV PER GE DRAWING

ADDED TERMINAL INFO. REF. DWG. REMOVED WIRE MARK. CONTACT O

G YZ RM DEG Rev 4/20/81

ADDED FITS INFORMATION PER PY-GEN/GAI-148

F YZ RM DEG Rev 11-9-80

REVISED FITS TERM. NOS PER GE REVISION

ADDED FITS INFORMATION REDRAWN TO MOVE ISOLATORS TO 4-0200-001

A RM DEG Rev 8-2-79

READING PA 044549-000 WW JGS DEG 04/11/81

GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS

NUCLEAR SAFETY RELATED

THE CLEVELAND ELECTRIC ILLUMINATING CO. PERRY NUCLEAR POWER PLANT UNIT 1 ELECTRICAL-ELEMENTARY DIAGRAM

REACTOR RECIRCULATION SYSTEM RECIRCULATION PUMP 60000 BREAKER CONTROL 3B

OR 4540 18-202-015 039 AEB H DRAWING NUMBER

17

ELECTRICAL ENGINEER

17

Rids

82-2140011

