



- LEGEND:-**
- 6 EXTERNAL WIRE MARK (SEE NOTES 2 AND 3)
 - 6 INTERNAL WIRE MARK
 - SWITCHGEAR TERMINAL
 - AUX GE RELAY 12HG111J2
 - CLASS 1E DIVISION 2
 - NON-CLASS 1E

- NOTES:-**
1. ALL DEVICES WITHOUT LOCATION MARKS ARE IN SWITCHGEAR.
 2. ALPHABETICAL WIRE MARKS ARE PREFIXED BY: SUBSYSTEM NO., SHEET AND LINE NO. (EXAMPLE: #33A3G11C).
 3. POTENTIAL WIRE MARKS ARE PREFIXED BY: SUBSYSTEM NO., AND SHEET NO. (EXAMPLE: #33A30CP).
 4. DEVICE DESIGNATIONS ARE PREFIXED BY: UNIT AND SYSTEM NO. (EXAMPLE: 1033-S061S).
 5. FOR GRAPHIC STANDARDS, REFER TO DRS. 0-203-001.
 6. FOR RELAY STANDARDS, REFER TO DRS. 0-200-002.
 7. FOR SWITCH DEVELOPMENTS, REFER TO SHEETS 62 AND 03.

REFERENCES:-
829E446CA SHEET 23, G.E. CO. DRAWING

PRC
APERTURE
CARD

NUCLEAR SAFETY RELATED

CHANGED AUX RELAY LEGEND FROM CUTLER-HAMMER TO GE. AUX ADDED ATMS CIRCUITRY PER GE.		ADDED TERMINAL INFO		READING FA		GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS	
G MAR TAM 18 Jan 8/2/82		F YZ RM DEC RM 4/6/81		DATE RELEASED FOR		REACTOR RECIRCULATION SYSTEM RECIRCULATION PUMP COUPLER BREAKER 4B	
ADDED RED LIGHT FOR DUAL TRIP 201C.		REVISED FITS TERM. NOS PER GE REVISION		ADDED FITS INFORMATION REDRAWN TO MAKE FITS ATTORNS		THE CLEVELAND ELECTRIC ILLUMINATING CO. PERRY NUCLEAR POWER PLANT ELECTRICAL-ELEMENTARY DIAGRAMS	
B DUE 1/18/82		A 1/18/82		044549-000 UNW JGS		REACTOR RECIRCULATION SYSTEM RECIRCULATION PUMP COUPLER BREAKER 4B	

Rids

82-2140013

