



**LEGEND:**

- EXTERNAL WIRE MARK (SEE NOTES 2 AND 3)
- MCC TERMINAL (WITH DRAW OUT PROVISION)
- ✓ INTERNAL WIRE MARK
- VENDOR PNL - IE22-P001
- IHSI-P879 - DIV 3 LOCAL RELAY PANEL

**NOTES:**

- ALL DEVICES WITHOUT LOCATION MARKS ARE LOCATED IN M.C.C.
- ALPHABETICAL WIRE MARKS ARE PREFIXED BY: SYSTEM NO., SHEET NO., AND LINE NO. (EXAMPLE: E22B106A1)
- POTENTIAL WIRE MARKS ARE PREFIXED BY: SYSTEM NO. AND SHEET NO. (EXAMPLE: E22B106A1)
- DEVICE DESIGNATIONS ARE PREFIXED BY: UNIT AND SYSTEM NO. (EXAMPLE: IE22R-SSC)
- FOR GRAPHIC STANDARDS, REFER TO DRAWING B-208-001.

**REFERENCE:**  
 B-211-066 SH. 9 BLOCK DIAGRAM

PRC  
 APERTURE  
 CARD

SS2/VENDOR PNL	CONTROL SWITCH		
	CONTACTS	MAN. OFF	AUTO
1	X		
2		X	

X - CLOSED CONTACTS  
 (EX. SBM 10AA037, MAINT. CONTACTS)

NUCLEAR SAFETY RELATED

THE CLEVELAND ELECTRIC ILLUMINATING CO.  
 PERRY NUCLEAR POWER PLANT UNIT 1  
 ELECTRICAL-ELEMENTARY DIAGRAM  
 HIGH PRESSURE CORE SPRAY  
 JACKET WATER KEEP WARM HEATER  
 IE22-D010

REV	DATE	BY	CHKD	APPROVALS	DATE	REV	DATE	BY	CHKD	APPROVALS	DATE	REV	DATE	BY	CHKD	APPROVALS	DATE	REV	DATE	BY	CHKD	APPROVALS	DATE

ADDED IHSI-P879 REF N/A  
 ADDED RELAYS 274, 740, REF. CIRCUIT NO.  
 REV. TO NSR DIV. 3  
 READING PA. 044549-000  
 GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS  
 DATE RELEASED FOR ENGR. 7-15-77  
 PRELIMINARY  
 CONSTRUCTION  
 DATE 7-15-77  
 PA. 044549-000  
 MADE CHRD. DEL. APP. ENG. APP. DATE 7-15-77  
 DRAWING NUMBER B-208-066  
 SYSTEM NO. E22  
 SHEET NO. D010

RIDS

82L2160588

