



LEGEND:

- EXTERNAL WIRE MARK (SEE NOTES 2 AND 3)
- MCC TERMINAL (WITH DRAW OUT PROVISION)
- INTERNAL WIRE MARK
- VENDOR PNL - 1E22-P001
- CLASS 1E DIV. 3, THIS SHEET A
- IWS1-P879 DIV. 3 LOCAL RELAY PANEL

NOTES:

1. ALL DEVICES WITHOUT LOCATION MARKS ARE LOCATED IN D.C.C.
2. ALPHABETICAL WIRE MARKS ARE PREFIXED BY: SYSTEM NO., SHEET NO., AND LINE NO. (EXAMPLE E22B059)
3. POTENTIAL WIRE MARKS ARE PREFIXED BY: SYSTEM NO. AND SHEET NO. (EXAMPLE E22B059X)
4. DEVICE DESIGNATIONS ARE PREFIXED BY: UNIT AND SYSTEM NO. (EXAMPLE E22B-SS1)
5. FOR GRAPHIC STANDARDS, REFER TO DRAWING 0-208-001.

REFERENCE:
 22715 CE - STEWART & STEVENSON
 B-211-066 SH10 BLOCK DIAGRAM

SS1 / VENDOR PNL	CONTROL SWITCH			
	CONTACTS	MAN OFF	AUTO	CONTACT LOCATION
1-1c	1	X		07
2-1c	2		X	05

X - CLOSED CONTACTS
 G.E. SBM 10AA039 MAINT. CONTACTS

PRC
 APERTURE
 CARD

NUCLEAR SAFETY RELATED

THE CLEVELAND ELECTRIC ILLUMINATING CO.
 PERRY NUCLEAR POWER PLANT UNIT 1
 ELECTRICAL-ELEMENTARY DIAGRAM
 HIGH PRESSURE CORE SPRAY
 CIRCULATING OIL PUMP
 1E22-C007

ADDED IWS1-P879 REF.	ADDED RELAYS 27, 74P, REF. CIRCUIT NO.	REV. TO NSR DIV. 3	READING PA.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS	044549-000	NPS RAM DEG TFF	7-15-77	04	4549	B-208-066	E22	B107	C	
REV	MADE	CHKD	APPROVALS	DATE	REV	MADE	CHKD	APPROVALS	DATE	REV	MADE	CHKD	APPROVALS	DATE
C	W	P	DEG	7/12/77	46-3	B	L	W	7/12/77	8-2-81	A	M	J	R
ELEM DIAG 1E22-C007														

RIDS

8212160590

