



LEGEND

- LSO - LIMIT SWITCH OPENS IN FULL OPEN POSITION OF VALVE
- LSC - LIMIT SWITCH OPENS IN FULL CLOSED POSITION OF VALVE
- R - RED IND LIGHT (VALVE OPEN)
- G - GREEN IND LIGHT (VALVE CLOSED)

NOTES:

- 1. IH13-P715B TERMINATION CABINET
- LINE CODE 31 - TM073
- HOLD ALL OTHER TERMINATION INFO.

PRC APERTURE CARD

NUCLEAR SAFETY RELATED

REMOVED HOLD CONTACT FROM CHANGE PLUG AS F007 ED JACKS J21A, J154, ADDED INDICATOR LIGHTS, REV TITLE BLOCK PER GE DRAWING.

REVISED PER GE DRAWING 5/14/72

74 CONTACT ON HOLD

ADDED LEGEND

REVISED FITS INFO

ADDED FITS INFO TO LS11 ESI-F068

REDRAWN PER GE REV. 2

VALVE IES1-F066
TESTABLE CHECK VALVE

LOCAL IES1-F066

GENERAL ELECTRIC 428539CA
SMITH REV 6
REACTOR CORE ISLM COOLING SYS

7-28-77	CONSTRUCTION	TEF
	PRELIMINARY	
	RELEASED FOR	ENGR.
GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS		
044548-000	WORK ORDER	DATE
04	4549	1B-208-075
ES1	A08	F

THE CLEVELAND ELECTRIC ILLUMINATING CO.			
PSKRY NUCLEAR POWER PLANT UNIT 1			
ELECTRICAL-ELEMENTARY DIAGRAM			
REACTOR CORE ISOLATION COOLING SYSTEM STATUS LIGHTS AND 89V F066			
DRAWING NUMBER	SYSTEM	SH. NO.	REV.
4549	1B-208-075	ES1	A08 F

REV	MADE	CHKD	APPROVALS	DATE	REV	MADE	CHKD	APPROVALS	DATE	REV	MADE	CHKD	APPROVALS	DATE	REV	MADE	CHKD	APPROVALS	DATE										
E	YZ	RM	DEG	RAM	2-11-81	D	ESG	RAM	DEG	RAM	4-3-80	C	CYS	RAM	DEG	RAM	11-21-79	B	RAM	DPB	DEG	RAM	8-29-79	A	RAM	DPB	DEG	RAM	8-1-77

ELEM DIAG ES1A STATUS LTS & F066

REV D WCR 120

RIDS

82L2160691

