



- LEGEND:**
- EXTERNAL WIRE MARK (SEE NOTES 2 AND 3)
 - WIRE TERMINAL (WITH DRAW OUT PROVISION)
 - ✓ INTERNAL WIRE MARK
 - Ⓝ CLASS IF DIVISION 2
 - 74B-AGASTAT RELAY TYPE GF1GM
 - H13-P904-9280-TERMINATION CABINET
 - FM-TM00
 - H13-P704-COMMON HVAC PANEL
 - K3-AGASTAT TIMING RELAY TYPE 7012ACM
 - K4-AGASTAT CONTROL RELAY TYPE GF1GM
 - H13-P969-AUX. RELAY PNL.
 - K64-K30-ITE/GOULD J10A40:2
 - Ⓝ NON NUCLEAR SAFETY RELATED
 - K58-CUTLER HAMMER D26MR20A

- NOTES:**
1. ALL DEVICES WITHOUT LOCATION MARKS ARE LOCATED IN N.C.C.
 2. ALPHABETICAL WIRE MARKS ARE PREFIXED BY SYSTEM NO., SHEET NO., AND LINE NO. (EXAMPLE M250205A)
 3. POTENTIAL WIRE MARKS ARE PREFIXED BY SYSTEM NO. AND SHEET NO. (EXAMPLE M2502X1)
 4. DEVICE DESIGNATIONS ARE PREFIXED BY SYSTEM NO. (EXAMPLE M25-S2)
 5. FOR GRAPHIC STANDARDS, REFER TO DRAWING D-20C-301.

REFERENCE:
 SYSTEM DIAGRAM - D-712-610
 BLOCK DIAGRAM - B-21-17 SH.02

S2/H13-P904	CONTROL SWITCH			CONTACT LOCATION
	(CAM 15) CONTACTS	NAMEPLATE (FY)		
OPERATOR	STOP	AUTO	ON	
TR 1	X	X	X	05
TR 3	X	X	X	0624
BF 5	X	X	X	SPARE
BR 7	X	X	X	05
OPER & BLOCK				X-CLOSED CONTACT
CR2540-US203M				
SPRING RETURN FROM STOP				

PRO APERTURE CARD

Ⓝ Ⓝ NUCLEAR SAFETY RELATED

THE CLEVELAND ELECTRIC ILLUMINATING CO.			
PERRY NUCLEAR POWER PLANT		UNITS #2	
ELECTRICAL-ELEMENTARY DIAGRAM			
CONTROL ROOM HVAC			
SUPPLY FAN "B"			
M25-001B			

REVISED 3 PLACES AS PER IDCI #212 & ECN 245-033-01-160		REV. TERM. #0	ADDED K58 RELAY & CONTACT PER ECN 5306-24-210	REVISED RELAY TYPE PER ECN 245-033-01-92	ADDED FITS INFO, REFS DELETED: H13-P746 ON LINE 09, H13-P742 H13-P969 ON LINE 15, DELETED K11 LINE 15 ADDED REF	READING PA.	GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS	044549-000	TEL 393	DEG	TFF	8-25-70	04	4549	B-208-117	M25	02	E	
REV	MADE	CHKD	APPROVALS	DATE	REV	MADE	CHKD	APPROVALS	DATE	REV	MADE	CHKD	APPROVALS	DATE	REV	MADE	CHKD	APPROVALS	DATE
E	CH	R	W	10-01-71	C	M	2	10-01-71	A	U	1	10-01-71							

ELEM DIAG M25-001B

RIDS

8212170360

