



- LEGEND:**
- EXTERNAL WIRE MARK (SEE NOTES 2 AND 3)
 - MCC TERMINAL (WITH DRAW OUT PROVISION)
 - INTERNAL WIRE MARK
 - ⓓ CLASS 1E DIV. 3 THIS SHEET
 - ⓐ 1H13-P712 TERMINATION CABINET T-MOD 4
 - ⓑ 1H13-P800 - HVAC PANEL
 - ⓐ 74B, K14, K4 - AGASTAT G.P.I.G.M. RELAY
 - ⓑ K5 - TIME DELAY AGASTAT 7012ACM
 - ⓐ 1H13-P873 - AUX. RELAY CABINET
 - ⓑ K27 - CUTLER-HAMMER D26 MR20A

- NOTES:**
1. ALL DEVICES WITHOUT LOCATION MARKS ARE LOCATED IN M.C.C.
 2. ALPHABETICAL WIRE MARKS ARE PREFIXED BY: SYSTEM NO., SHEET NO., AND LINE NO. (EXAMPLE M43 02 05A)
 3. POTENTIAL WIRE MARKS ARE PREFIXED BY: SYSTEM NO. AND SHEET NO. (EXAMPLE M43 02 X2)
 4. DEVICE DESIGNATIONS ARE PREFIXED BY: UNIT AND SYSTEM NO. (EXAMPLE M43-52)
 5. FOR GRAPHIC STANDARDS, REFER TO DRAWING B-208-001.

REFERENCE:
SYSTEM DIAGRAM Dwg. NO. D-912-619
BLOCK B-211-135 SH2

52/1H13-P800		CONTROL SWITCH			
CR2340-U200E (CAM 1E) CONTACTS		NAMEPLATE (F.V.)		CONTACT	
OPERATOR		STOP	AUTO START	LOCATION	
TF 1	2		X	X	05
TR 3	4	X			11
BF 5	6	X	X		SPARE
BR 7	8			X	05
TR 9	10		X	X	15
TR 11	12	X			SPARE
TANDEM BLOCK CR2340-U200E		X - CLOSED CONTACTS			
SPRING RETURN TO AUTO					

PRO APERTURE CARD

ⓓ3 NUCLEAR SAFETY RELATED
THE CLEVELAND ELECTRIC ILLUMINATING CO.
PERRY NUCLEAR POWER PLANT UNIT 1
ELECTRICAL-ELEMENTARY DIAGRAM
DIESEL GEN. BLDE. VENTILATION SYSTEM
VENTILATION FAN COCIC

ADDED K4 CONTACT REF.		ADDED IF54-N3571-1		ADD REF TO ECN 245-033-01 ATT 160. IDENTIFIED E22-K204 CONTACTS.		ADDED K27 PER ECN 5306-24 216 REV CONTACT REF. 5 TERM. REF.		READING PA.		GILBERT ASSOCIATES, INC. ENGINEERS AND CONSULTANTS		044549-000 HIG GRZ DEG 11/30/77		
ADDED FITS INFO.		CEN049 IP54-N3571-1 AND ADDD P51-K40, ECN245-033-01%		CAG RAM REG 9-17-77		H P RAM 8-11-77		G P M 11-16-77		044549-000 HIG GRZ DEG 11/30/77		04 4549 B-208-135 M43 02 H		
REV	MADE	CHKD	APPROVALS	DATE	REV	MADE	CHKD	APPROVALS	DATE	REV	MADE	CHKD	APPROVALS	DATE
E	RAM	RAM	REG	10-17-70	D	WJL	RAM	DEGR	10-17-70	C	CAG	RAM	REG	9-17-77
ELEM DIAG M43-C001C														

RIDS

82L2170 430

